

# memorandum

DATE: December 8, 2017

REPLY TO  
ATTN OF: EP-4

SUBJECT: Supplement Analysis for the Transmission System Vegetation Management Program FEIS (DOE/EIS-0285/SA-679)

TO: Jacob Marti  
Natural Resource Specialist – TFBV-The Dalles

**Proposed Action:** Vegetation management along the Pilot Butte – La Pine No.1 and Jones Canyon – Santiam No. 1 Corridors

**Pollution Prevention and Abatement Project No.:** 3751

**Location:** Marion, Wasco, and Deschutes County, Oregon

**Proposed by:** BPA

**Description of the Proposal:** BPA proposes to clear unwanted vegetation along and adjacent to the transmission line corridor and access roads along the 230-kilovolt (kV) Pilot Butte – La Pine No. 1 transmission line corridor from towers 1/1 to 30/9 and Jones Canyon – Santiam No. 1 transmission line corridor from towers 75/2 to 102/3. The right-of-way (ROW) corridor in the Pilot Butte – La Pine No. 1 proposed project area measures 125 feet in width and crosses approximately 30 miles of terrain through rural residential, agricultural, the Deschutes National Forest, and private lands. The right-of-way (ROW) corridor in the Jones Canyon – Santiam No. 1 proposed project area measures 250 feet in width and crosses approximately 24 miles of terrain through the Confederated Tribes of the Warm Springs Reservation.

Letters, on-site meetings, emails, and phone calls would be used to notify landowners approximately three weeks prior to commencing vegetation management activities. Door hangers would also be used at properties where special treatments are anticipated. Letters were mailed to the Confederated Tribes of the Warm Spring in November 2017 and coordination with the Deschutes National Forest occurred in September 2017.

In order to comply with Western Electricity Coordinating Council (WECC) standards, BPA proposes to manage vegetation with the goal of removing tall growing vegetation that is currently or will soon become a hazard to the transmission line (a hazard is defined as one or more branches, tops, and/or whole trees that could fall or grow into the minimum safety zone of the transmission line(s) causing an electrical arc, relay and/or outage). The overall goal of BPA is to establish low-growing plant communities along the ROW to control the development of potentially threatening vegetation.

A combination of selective and nonselective vegetation control methods that may include hand cutting and herbicidal treatment would be used to perform the work. Herbicides would be selectively applied using spot treatment (stump or stubble treatment, basal treatment, and/or spot foliar), or localized treatments (broadcast application and cut stubble treatments) with chemicals approved in BPA's Vegetation Management EIS, to ensure that the roots are killed preventing new sprouts and selectively eliminating vegetation that interferes with the operation and maintenance of transmission infrastructure. The proposed project would begin in the spring of 2018 and be completed by fall of 2018. To prevent trees from coming into contact with the energized conductors, BPA proposes to remove up to 5 trees in or adjacent to the ROW. Debris would be disposed of using onsite chip, lop, and scatter, or mulching techniques. All onsite debris would be scattered along the ROW.

**Analysis:** A Vegetation Control Prescription & Checklist was developed for this corridor that incorporates the requirements identified in BPA's Transmission System Vegetation Management Program FEIS (DOE/EIS-0285, May 2000) and Record of Decision (August 23, 2000). The following summarizes natural resources occurring in the project area along with applicable mitigation measures outlined in the Vegetation Control Prescription.

**Water Resources:** Water bodies (streams, rivers, lakes, wetlands) occurring in the project area are noted in the Vegetation Control Prescription. As conservation and avoidance measures, only spot and localized treatment with Garlon 3A (Triclopyr TEA) would be used within a 100-foot buffer up to the water's edge of any stream containing threatened or endangered species. Trees in riparian zones would be selectively cut to include only those that will grow into the minimum approach distances of the conductor at maximum sag, other trees would be left in place or topped to preserved shade. Shrubs that are less than 10-feet-high would not be cut where ground to conductor clearance allows. No ground disturbing vegetation management methods would be implemented thus eliminating the risk for soil erosion and sedimentation near the streams. For location information, see the Vegetation Control Prescription.

**Threatened and Endangered Species:** Pursuant to its obligations under the Endangered Species Act (ESA), BPA has made a determination of whether its proposed project would have any effects on any listed species. A species list was obtained for federally-listed, proposed and candidate species potentially occurring within the project boundaries from the United States Fish and Wildlife Service (USFWS). Based on the ESA review conducted, BPA made a determination that the project would have "No Effect" for all ESA-listed species under USFWS' jurisdiction. BPA also conducted a review of species under the jurisdiction of the National Oceanic and Atmospheric Administration, National Marine Fisheries Service (NOAA Fisheries). A determination of "No Effect" was made for all ESA-listed species under NOAA Fisheries' jurisdiction, with the implementation of the conservation measures in Water Resources section above.

**Essential Fish Habitat:** A review of the NOAA Fisheries database identified Essential Fish Habitat (EFH) streams occurring in the project area. Measures identified for water resources would be followed for EFH. Based on project conservation measures, it was determined that the project would not adversely affect EFH.

Cultural Resources: No cultural resources are known for the project area. If a site is discovered during the course of vegetation control, work would be stopped in the vicinity and the BPA Environmental Specialist, and the BPA archeologist would be contacted.

Re-Vegetation: Native grasses are present on the entire ROW and are expected to naturally seed into the areas that would have lightly-disturbed soil predominately located on the ROW roads.

Monitoring: The entire project would be inspected during the work period, spring 2018. Additional monitoring for follow-up treatment would be conducted as necessary. A vendor scorecard of inspection results would be used to document formal inspections and will be filed with the contracting officer.


Findings:

This Supplement Analysis finds that: (1) the proposed actions are substantially consistent with the Transmission System Vegetation Management Program FEIS (DOE/EIS-0285) and ROD, and; (2) there are no new circumstances or information relevant to environmental concerns and bearing on the proposed actions or their impacts. Therefore, no further NEPA documentation is required.



Michelle Colletti  
Physical Scientist, EPR-4

CONCUR:



Stacy Mason  
NEPA Compliance Officer

DATE: December 8, 2017

References:

Vegetation Management Prescription and Checklist  
Effects Determination