

B O N N E V I L L E
P O W E R A D M I N I S T R A T I O N



**Available Transfer Capability
Implementation Document
(North American Energy Standards Board WEQ-023)**

**Bonneville Power Administration
Transmission Services**

Effective Date: February 13, 2024

Contents

I. Purpose	1
II. Definitions	1
III. Overview	2
Methodology Selected	2
Rated System Path Methodology, WEQ-023-2.2	2
ATC Calculations	2
ATC Calculation Periods	2
Frequency of ATC Recalculation	2
IV. Allocation Processes	2
V. Outages	3
Outage Planning	3
Outage Criteria for TTC Calculations	3
VI. Priorities Used to Set TTC.....	4
VII. Rated System Path Methodology for BPA's Paths	5
BPA's Paths	5
Calculating TTC	9
Data and Assumptions.....	9
Process to Determine TTC	10
Calculating Firm Transmission Service for Paths	12
Calculating Firm Existing Transmission Commitments (ETC _F)	12
Determining base ETC for Flow-Based Paths	14
Calculating Interim ETC _F for Flow-based Paths	18
Calculating Firm Available Transfer Capability (ATC _F)	20
Calculating Non-Firm Transmission Service for BPA's Paths	22
Calculating Non-Firm Existing Transmission Commitments (ETC _{NF})	22
Calculating Non-Firm Available Transfer Capability (ATC _{NF}).....	24
Adjustments to Flow-based Path ATC Values	30
VIII. Responding to Methodology/Documentation Clarifications and/or Data Requests	30
IX. ATCID Revisions	31

3 I. Purpose

4 This Available Transfer Capability Implementation Document (ATCID) addresses all of the
5 requirements of North American Energy Standards Board (NAESB) Wholesale Electric Quadrant
6 business practice standard 023 (WEQ-023), and includes BPA's Postback Methodology.

7 This ATCID only applies to ATC calculations through month 13.

8 II. Definitions

9 All capitalized terms used in this ATCID are either contained in NERC's Glossary of Terms,
10 NAESB WEQ-000, or are defined in this ATCID.

11 Defined terms specific to BPA include:

- 12 • **Federal Columbia River Power System (FCRPS):** The Transmission System
13 constructed and operated by BPA and the 31 federally-constructed hydroelectric dams¹
14 on the Columbia and Snake Rivers, and the Columbia Generating Station nuclear plant.
15 Each entity is separately managed and financed, but the facilities are operated as an
16 integrated power System.
- 17 • **Federal Columbia River Transmission System (FCRTS):** The FCRTS is comprised of
18 BPA's main grid network Facilities (Network), Interconnections with other
19 Transmission Systems (External Interconnections²), Interties,³ delivery Facilities,
20 subgrid Facilities, and generation Interconnection Facilities within the Pacific
21 Northwest region and with western Canada and California.
- 22 • **Long-Term Reservation:** a confirmed reservation that has duration greater than or
23 equal to 365 days
- 24 • **Short-Term Reservation:** a confirmed reservation that has duration less than 365
25 days

¹ Albeni Falls, Anderson Ranch, Big Cliff, Black Canyon, Boise River Diversion, Bonneville, Chandler, Chief Joseph, Cougar, Detroit, Dexter, Dworshak, Foster, Grand Coulee, Green Peter, Green Springs, Hills Creek, Hungry Horse, Ice Harbor, John Day, Libby, Little Goose, Lookout Point, Lost Creek, Lower Granite, Lower Monumental, McNary, Minidoka, Palisades, Roza and The Dalles

² Northern Intertie, Reno-Alturas, West of Hatwai, West of Garrison and La Grande paths.

³ AC Intertie (NWACI), Pacific DC Intertie (PDCI), and Montana Intertie.

26 III. Overview

27 BPA owns and provides Transmission Service over the FCRTS. BPA is registered with NERC as a
28 Transmission Operator (TOP) and Transmission Service Provider (TSP), among other
29 registrations.

30 Methodology Selected

31 Rated System Path Methodology, WEQ-023-2.2

32 BPA has elected to use the Rated System Path Methodology to calculate Total Transfer
33 Capability (TTC) and Available Transfer Capability (ATC) for all its paths. The description
34 of how BPA implements this methodology for these paths is included in this ATCID.

35 ATC Calculations

36 ATC Calculation Periods

37 BPA calculates ATC values using the Rated System Path Methodology for the following time
38 periods:

- 39 • Hourly values for up to 168 hours. The next hour may be calculated in subhourly
40 intervals, with the most limiting subhourly ATC value being the hourly value.
- 41 • Daily values for day 3 through day 90. For days 3 to 7 (up to hour 168), the daily ATC
42 value is the most limiting hourly ATC value for that day.
- 43 • Monthly values for month 2 through month 13. For months 2 and 3 (up to day 90), the
44 monthly ATC value is the most limiting daily ATC value for that month.

45 Frequency of ATC Recalculation

46 BPA recalculates ATC on the following frequency, even if the calculated values
47 identified in the ATC equation are unchanged:

- 48 • Hourly, at least once per hour
- 49 • Daily, at least once per day
- 50 • Monthly, at least once per day

51 BPA may recalculate ATC values more frequently due to changes in Total Transfer
52 Capability (TTC), Power Transfer Distribution Factors (PTDFs), system issues or as deemed
53 necessary.

54 IV. Allocation Processes

55 BPA allocates transfer capability among multiple owners or users of its 1:1 and flow-based
56 paths.

57 **Allocations - TTC:**

58 For paths where allocation agreements exist, BPA allocates TTC according to the
59 contractual rights of the various owners as defined in the agreements.

60 Allocation agreements do not exist for two of BPA’s flow-based paths that have multiple
61 owners: Columbia Injection N>S and Wanapum Injection N>S. For Columbia Injection N>S
62 and Wanapum Injection N>S, BPA determines its share of TTC based on BPA-owned
63 transmission lines that make up these paths when all lines are in service. During outage
64 conditions, individual allocations exist for the loss of each transmission line in the line
65 definitions for these paths.

66 **Allocations - base ETC:**

67 BPA allocates base ETC among some of its shared flow-based paths. To allocate base ETC
68 for South of Allston N>S, BPA uses the contractual rights defined in the South of Allston
69 allocation agreement. To allocate base ETC for the Columbia Injection N>S, Wanapum
70 Injection N>S, and Cross Cascades North E>W paths, BPA only models the BPA-owned
71 transmission lines that make up these paths in the base ETC cases. BPA does not allocate
72 base ETC across any other shared flow-based paths.

73 **Allocations - PTDFs:**

74 BPA calculates PTDFs based on the full path definition of all paths with the exception of
75 Columbia Injection N>S, Wanapum Injection N>S and Cross Cascades North E>W. For these
76 three paths, BPA calculates PTDFs based on the BPA-owned transmission lines that make
77 up these paths.

78 **V. Outages**

79 Outages from all TSPs that are internal or adjacent to BPA’s Balancing Authority Area (BAA)
80 can be mapped to the WECC base cases.

81 **Outage Planning**

82 Outage plans and the policy are posted to the Outage Plans website at: [Outage Coordination -
83 Bonneville Power Administration \(bpa.gov\)](http://www.bpa.gov/OutageCoordination)

84 **Outage Criteria for TTC Calculations**

85 BPA incorporates outages into the TTC calculations after they have been studied by BPA or
86 provided to BPA by another TOP. Generally, BPA studies outages 10 to 16 days prior to the
87 outage start date.

88 The duration of an outage is not a criteria by which BPA determines which outages to
89 incorporate in its daily and monthly TTC calculations. The most conservative hourly TTC
90 calculated for a given outage or combination of outages becomes the governing TTC for the
91 daily calculation period. Likewise, the most conservative daily TTC for a given outage or
92 combination of outages becomes the governing TTC for the monthly calculation period.

93 VI. Priorities Used to Set TTC

94 BPA may update assumptions and calculate new TTCs when changes to System conditions will
95 significantly impact those limits and may use those updated assumptions to determine new
96 TTC values. The following hierarchy of priorities categorizes the TTC values based on the
97 time period being calculated and the reason for the change. This prioritization may then be
98 used to revise the path TTC for a given time period if BPA determines that more recent
99 assumptions to calculate TTC values better reflect updated System information:

- 100 • **Real-time limit (highest priority):** The “Real-time limit” priority governs when BPA
101 updates the assumptions of System conditions to calculate TTCs during the Real-time
102 horizon. A change to the TTC calculation with the Real-time priority governs all other
103 priorities. For example, if BPA receives an update that a scheduled outage will be
104 extended by two hours early in the Real-time day, BPA may update the assumptions
105 for the TTC calculation accordingly for the additional two hours and may use those
106 same updated assumptions to update the TTC. If there are multiple real-time updates
107 to assumptions for TTC calculations, the most recent TTC calculated governs.
- 108 • **Scheduling limit:** The “scheduling limit” priority may be used occasionally when the
109 assumptions for the TTC are not governing or an actual scheduling limit has been
110 imposed. If there is more than one scheduling limit, the lowest scheduling limit
111 governs until a Real-time limit TTC is submitted.
- 112 • **Pre-schedule forecast:** The “pre-schedule forecast” TTC priority may be used for a
113 path if the assumptions for the TTC calculations are updated for the pre-schedule
114 period. For example, for TTCs calculated for flow-based paths that are derived using
115 nomograms, if the assumptions are re-evaluated just prior to the pre-schedule day to
116 incorporate updated data inputs, the TTC may be updated. The pre-schedule forecast
117 TTC governs over the ‘studied’ priority.
- 118 • **Studied:** The “studied” priority is used when there are outages where a study report
119 has been issued, including those provided by other TOPs. For example, if a study
120 report is issued evaluating assumptions for line outage system conditions, the TTCs in
121 that report govern over any lower-priority TTCs for the duration of the line outage
122 conditions.
- 123 • **Estimated known limit:** The “estimated known limit” priority is used to establish
124 unstudied TTCs or to define seasonal path TTCs that govern over “short-term
125 seasonal” or “Path Rating” priorities.
- 126 • **Short-term seasonal:** The “short-term seasonal” priority is used for TTCs issued for
127 seasonal Path Ratings. As these Ratings may be higher at certain times during the
128 year, the short-term seasonal priority governs over the Path Rating priority. For
129 example, if the longer-term Path Rating for a path is 7800 MW, but seasonally this
130 Rating increases to 8000 MW, the short-term seasonal Rating of 8000 MW governs and
131 is used to set the TTC during the season to which it applies.
- 132 • **Path Rating:** The “Path Rating” priority is used to set base TTCs using either the
133 Rating of the paths, TTCs studied using normal conditions, TTCs calculated for the
134 planning horizon, or all of the above. The lowest value resulting from the above
135 calculations governs for the given time period and is used to set the TTC. For
136 example, if under normal conditions the TTC for a path is 4410 MW, but the TTC
137 calculated for the planning horizon is 4100 MW, the lower TTC of 4100 MW governs and
138 is used to set the TTC for the path.

- **Informational limit (lowest priority):** The “informational limit” is used while establishing the initial setup of paths within the scheduling and reservation system. The informational limit is equal to the initial Path Rating of the path.

VII. Rated System Path Methodology for BPA’s Paths

This section describes how BPA implements the Rated System Path methodology for its paths.

BPA’s Paths

The following tables list BPA’s paths. BPA has a combination of 1:1 and flow-based paths, and uses the Rated System Path methodology to calculate ATC for both.

Table 1, BPA’s 1:1 Paths

1:1 Path Name	Direction	1:1 OASIS Path Name
Northern Intertie	N>S	NI_TOTL_N>S
Northern Intertie	S>N	NI_TOTL_S>N
West of Garrison	E>W	WOGARR_E>W
West of Garrison	W>E	WOGARR_W>E
La Grande	W>E	LAGR_W>E
La Grande	E>W	LAGR_E>W
Montana Intertie	E>W	MI_E>W
Reno-Alturas	N>S	RATS_N>S
Reno-Alturas	S>N	RATS_S>N
AC Intertie (NWACI)	N>S	AC_N>S
AC Intertie (NWACI)	S>N	AC_S>N
Pacific DC Intertie (PDCI)	S>N	DC_S>N
Pacific DC Intertie (PDCI)	N>S	DC_N>S
Rock Creek Wind	Gen	ROCKCK_GEN
John Day Wind	Gen	JDWIND_GEN
Satsop Injection	Gen	SATSOP_GEN

Table 2, BPA's Flow-Based Paths

Flow-based Path Name	Direction	Flow-based OASIS Path Name	Transmission Line Components	Case used for base ETC calculation
North of Hanford	N>S	NOHANF	Vantage-Hanford #1 500-kV; Grand Coulee-Hanford #1 500-kV; and Shultz-Wautoma #1 500-kV	Heavy load
North of Hanford	S>N	NOHANF_S>N	Hanford-Vantage #1 500-kV; Hanford-Grand Coulee #1 500-kV; and Wautoma-Shultz #1 500-kV	Heavy load
South of Allston	N>S	SOALSN	BPA-Owned Transmission Lines: Allston-Keeler 500-kV; Lexington-Ross 230-kV; and Allston-St. Helens 115-kV; Portland General Electric-Owned Transmission Lines: Trojan-St. Marys 230-kV; and Trojan-Harborton 230-kV; PacifiCorp-Owned Transmission Lines: Merwin-St. Johns 115-kV; Astoria-Seaside 115-kV; and Clatsop 230/115-kV	Heavy load
Raver-Paul	N>S	RAVR_PAUL	Raver-Paul #1 500-kV When Raver-Paul #1 500-kV is out of service, the following lines are monitored: Raver-Paul #1 500-kV; St. Clair-South Tacoma #1 230-kV; Chehalis-Covington #1 230-kV; Frederickson-St. Clair 115-kV; and Electron Heights-Blumaer 115-kV	Heavy load
Cross Cascades North	E>W	C-CASC_N	BPA-Owned Transmission Lines: Schultz-Raver #1, #3, & #4 500-kV; Schultz-Echo Lake #1 500-kV; Chief Joseph-Monroe #1 500-kV; Chief Joseph-Snohomish #3 & #4 345-kV; Rocky Reach-Maple Valley #1 345-kV; Grand Coulee-Olympia #1 287-kV; and Bettas Road-Covington #1 230-kV; Puget Sound Energy-Owned Transmission Line: Rocky Reach-Cascade 230-kV	Heavy load

Flow-based Path Name	Direction	Flow-based OASIS Path Name	Transmission Line Components	Case used for base ETC calculation
Cross Cascades South	E>W	C-CACS_S	<p>BPA-Owned Transmission Lines: Big-Eddy-Ostrander #1 500-kV; Ashe-Marion #2 500-kV; Buckley-Marion #1 500-kV; Knight-Ostrander #1 500-kV; John Day-Marion #1 500-kV; McNary-Ross #1 345-kV; Big Eddy-Chemawa #1 230-kV; Big Eddy-McLoughlin #1 & #2 230-kV; Midway-North Bonneville #1 230-kV; Jones Canyon-Santiam #1 230-kV; and Big Eddy-Troutdale #1 230-kV</p> <p>PGE-Owned Transmission Line: Round Butte-Bethel 230-kV</p>	Heavy load
West of McNary	E>W	WOMCNY	Coyote Springs-Slatt #1 500-kV; McNary-Ross #1 345-kV; Harvalum-Big Eddy #1 230-kV; Jones Canyon-Santiam #1 230-kV; and McNary-John Day #2 500-kV	Heavy load
West of Slatt	E>W	WOSLATT	Slatt-Buckley #1 500-kV; and Slatt-John Day #1 500-kV	Heavy load
West of John Day	E>W	WOJD_E>W	John Day-Big Eddy #1 500-kV; John Day-Big Eddy #2 500-kV; and John Day-Marion #1 500-kV	Heavy load
South of Boundary	N>S	SBNDRY_N>S	Boundary-Bell #1 230-kV; Boundary-Bell #3 230-kV; Boundary-Usk #1 230-kV; and Boundary 230/115-kV Transformer #1	Heavy load
Columbia Injection	N>S	CLMBIA_N>S	<p>BPA-Owned Transmission Lines: Columbia-Grand Coulee #1 230-kV; Columbia-Grand Coulee #3 230-kV; Columbia-Rocky Reach #1 230-kV; Columbia-Valhalla #1 115-kV; and Columbia-Valhalla #2 115-kV;</p> <p>Chelan PUD-Owned Transmission Line: Columbia-Rocky Reach #2 230-kV</p> <p>Douglas PUD-Owned Transmission Line: Rapids-Columbia #1 230k</p>	Heavy load

Flow-based Path Name	Direction	Flow-based OASIS Path Name	Transmission Line Components	Case used for base ETC calculation
Wanapum Injection	N>S	WANAPM_N>S	BPA-Owned Transmission Line: Vantage-Midway #1 230-kV; Grant PUD-Owned Transmission Line: Priest Rapids-Midway #3 230-kV	Heavy load
West of Lower Monumental (West of LoMo)	E>W	W_LOMO_E>W	Lower Monumental-Ashe 500-kV; Lower Monumental-Hanford 500-kV; and Lower Monumental-McNary 500-kV	Heavy load
North of Echo Lake	S>N	N_ECOL_S>N	Echo Lake-Monroe-SnoKing Tap #1 500-kV; Echo Lake-Maple Valley #1 500-kV; Echo Lake-Maple Valley #2 500-kV; and Covington-Maple Valley #2 230-kV	Heavy load
South of Custer	N>S	SCSTER_N>S	Custer-Monroe #1 500-kV; Custer-Monroe #2 500-kV; Custer-Bellingham #1 230-kV; and Custer-Murray #1 230-kV	Heavy load
North of Grizzly	N>S	GRZN_N>S	Buckley-Grizzly #1 500-kV; John Day-Grizzly #1 500-kV; John Day-Grizzly #2 500-kV; and Maupin-Redmond #1 230-kV	Heavy load
North of Pearl	S>N	NOPE_S>N	BPA-Owned Transmission Line: Pearl-Keeler #1 500-kV; BPA/Portland General Electric Jointly Owned Lines: Pearl-Sherwood #1 & #2 230-kV; Pearl Tap to the Mcloughlin-Sherwood #1 230-kV	Heavy load
West of Hatwai	E>W	WOH_E>W	Hatwai-Lower Granite #1 500-kV; Bell-Grand Coulee #6 500-kV; Bell-Grand Coulee #3 230-kV; Bell-Grand Coulee #5 230-kV; Westside-Grand Coulee #1 230-kV; Dry Creek-Talbot 230-kV; North Lewiston-Tucannon River #1 115-kV; Devils Gap-Stratford 115-kV; Lind-Warden 115-kV; Creston-Bell #1 115-kV; and Dry Gulch-Pomeroy 69-kV	Light load

149 **Calculating TTC**

150 **Data and Assumptions**

151 When calculating TTC for its paths, BPA uses WECC base cases that utilize data and
152 assumptions consistent with the time period being studied.

153 BPA uses the following data and assumptions in the WECC base cases when calculating
154 TTCs for its paths:

155 BPA models all existing System Elements, including but not limited to any transmission
156 additions and retirements, in their normal operating condition for the assumed initial
157 conditions, up to the time horizon in which BPA begins modeling planned outages.

158 The WECC base cases include generators and phase shifters that meet the guidelines
159 set out in the WECC Data Preparation Manual.

160 BPA uses the seasonal Load forecasts contained in the WECC base cases for each BA.

161 Generation and Transmission Facility additions and retirements within the WECC
162 footprint are included in the WECC seasonal operating base cases for the season in
163 which they are energized/de-energized, respectively. BPA engineers modify the WECC
164 base cases to reflect the actual dates of energization/de-energization, as well as
165 expected generation for the timeframe under study.

166 The WECC base cases include Facility Ratings as provided to WECC by the Transmission
167 Owners and Generator Owners.

168 If Facility changes are made by BPA or another entity, then the base cases will be
169 updated to reflect these changes with a mid-season update.

170 The approved seasonal operating base cases that include the Facility changes will not
171 be used until 0 to 16 days prior to the energization or implementation of the Facility
172 change.

173 For periods beyond two weeks, the WECC base cases will be updated as necessary to
174 perform seasonal studies for the current or upcoming season in accordance with the
175 current BPA study processes.

176 For all paths, except West of Garrison and Northern Intertie South to North, BPA uses
177 the all lines in service TTC from the relevant seasonal studies when there are no
178 studied outages to set the TTC of the path for the corresponding seasonal time
179 periods.

180 For West of Garrison, for the seasons or time periods in which the seasonal studies
181 have not been completed, the most recent year's seasonal study results will be used
182 for setting the TTC for the path.

183 For Northern Intertie South to North, for the seasons or time periods in which the
184 seasonal studies have not been completed, the most recent year’s seasonal study
185 results will be used for setting the TTC. BPA uses the minimum TTC from the relevant
186 seasonal studies to set the TTC of the path for periods from the next day and
187 beyond. For the Real-time horizon, when there are no studied outages, BPA uses the
188 maximum TTC from the relevant seasonal studies to set the TTC of the path.

189 BPA models Special Protection Systems (BPA uses the term Remedial Action Schemes
190 or RAS) that currently exist or are projected for implementation within the studied
191 time horizon.

192 The WECC base cases include all series compensation for each line at the expected
193 operating level.

194 BPA uses no other modeling requirements for calculating TTC in addition to those
195 specified in this document.

196 **Process to Determine TTC**

197 BPA adjusts generation and Load levels, and planned outages, within the WECC power-
198 flow base cases to determine the TTC that can be simulated for each of its paths, while at
199 the same time satisfying all operations planning criteria contingencies, as follows:

200 BPA studies single and multiple contingencies that are relevant to the path being studied.

201 When modeling normal conditions, BPA models all Transmission Elements in BPA’s BAA and
202 adjacent BAAs at or below 100 percent of their continuous Rating. Any reliability
203 constraints requested by another Transmission Operator will also be included.

204 BPA models contingencies as per the current version of “RC West System Operating Limits
205 Methodology for the Operations Horizon” (RC West SOL Methodology) posted on RC West’s
206 website.

207 When modeling contingencies, BPA determines TTCs by stressing the system until flows
208 exceed emergency Facility Ratings or voltages fall outside emergency system voltage
209 limits (i.e., the post-Contingency state). BPA does this by simulating transfers performed
210 through the adjustment of generation and load. If a facility does not have an emergency
211 Facility Rating, the normal Facility Rating is used. If there is no emergency system voltage
212 limit, the normal system voltage limit is used. By meeting the criteria in the RC West SOL
213 Methodology, uncontrolled separation should not occur. BPA does not take into account
214 expected transmission uses in the determination of TTC.

215 BPA’s paths listed below are bi-directional and have studied TTCs in both the prevailing
216 and non-prevailing direction of flow.

- 217 • Northern Intertie
- 218 • West of Garrison
- 219 • La Grande
- 220 • Reno-Alturas
- 221 • AC Intertie (NWACI)
- 222 • Pacific DC Intertie (PDCI)

223 • North of Hanford

224 All of BPA's other paths are one directional, in the prevailing direction of flow, and have
225 studied TTCs that are established for the prevailing direction of flow.

226 For paths where TTC varies due to simultaneous interaction with one or more other paths,
227 BPA develops a nomogram, represented either by an equation or its graphical
228 representation, describing the interaction of the paths and the resulting TTC under
229 specified conditions. BPA then calculates a value, based on that nomogram and
230 forecasted System conditions for the time period studied, to develop its TTC values for
231 the affected paths.

232 BPA or the adjacent path TOP identifies when the new or increased TTC for a path being
233 studied by BPA or the adjacent path TOP has an adverse impact on the TTC value of
234 another existing path by modeling the flow on the path being studied at its proposed new
235 TTC level, while simultaneously modeling the flow on the existing path at its TTC level. In
236 doing so, BPA or the adjacent path TOP honors the reliability criteria described above.
237 BPA or the adjacent path TOP includes the resolution of this adverse impact in its study
238 report for the path.

239 BPA has Transmission Ownership Agreements where multiple ownerships of Transmission
240 rights exist on a path. TTC for the affected paths is allocated according to contractual
241 ownership rights.

242 The ratings for BPA's paths whose ratings were established, known, and used in operation
243 since January 1, 1994, have been re-established using updated methods. BPA studies its
244 paths, with the exception of La Grande, on a periodic basis and reconfirms the rating of
245 each path based on these studies. These ratings are then used to establish the TTC for
246 the path.

247 For the La Grande path, BPA uses the Accepted Rating of the path as defined in the WECC
248 Path Rating Catalog. BPA's La Grande path is part of the NW-Idaho path (WECC Path
249 14). The rating of Path 14 was reconfirmed through an updated study in 2010 when the
250 path definition had to be modified due to the addition of the Hemingway Substation by
251 PacifiCorp and Idaho Power.

252 BPA establishes the TTC at the lesser of the maximum allowable contractual allocation, or
253 the reliability limit determined by the Transmission Operator. The reliability limit
254 includes, but is not limited to, any System Operating Limit for an ATC path.

255 BPA creates a study report that describes the TTC applicable to the outages during the
256 studied time period and includes the limiting Contingencies and the limiting cause for the
257 calculated TTC. The RC West SOL Methodology document defines the steps taken and
258 assumptions BPA used to determine TTC for each path. BPA creates a study report for
259 each study it performs. The study report relies on the basic assumptions included in RC
260 West SOL methodology and identifies any changes to those basic assumptions.

261 Information regarding TTCs is shared electronically between the appropriate BPA
262 organizations within seven calendar days of the finalization of the study report for the TTCs.
263 BPA sends a notice to all TSPs for the paths listed in Table 1 where there are multiple TSPs
264 prior to limitations in TTCs.

265 A path for which BPA does not perform studies to determine the most current value of TTC is
266 Reno - Alturas. For Reno-Alturas, NV Energy determines TTC. The TTC is provided to BPA and
267 BPA then sends a Notice of Planned Path Limitation.

268 **Calculating Firm Transmission Service for Paths**

269 **Calculating Firm Existing Transmission Commitments (ETC_F)**

270 When calculating ETC_F for all time periods for its paths, BPA uses the following algorithm:

$$271 \text{ETC}_F = \text{NL}_F + \text{NITS}_F + \text{GF}_F + \text{PTP}_F + \text{ROR}_F + \text{OS}_F$$

272 **Where:**

273 ETC_F is the firm ETC for the ATC path.

274 **NL_F** is the firm capacity set aside to serve peak Native Load forecast commitments, to include
275 losses, and Native Load growth, not otherwise included in Transmission Reliability Margin or
276 Capacity Benefit Margin.

277 BPA does not have any NL_F, and thus sets NL_F at zero for all of its paths for all time
278 periods. All of BPA's firm Transmission obligations are captured in the NITS_F, PTP_F, GF_F
279 and ROR_F components of the ETC_F algorithm.

280 **NITS_F** is the firm capacity reserved for Network Integration Transmission Service serving Load,
281 to include losses, and Load growth, not otherwise included in Transmission Reliability Margin
282 or Capacity Benefit Margin.

283 For BPA's 1:1 paths, BPA uses ten year maximum 1 in 10 coincidental peak load forecasts
284 to encumber capacity for customers with a designated resource of FCRPS. For customers
285 with a designated resource outside of FCRPS, BPA uses the capacity designated for the
286 resource to encumber capacity across these paths.

287 On the La Grande W>E ATC path, BPA uses a different methodology to encumber capacity
288 for customers with a designated resource of FCRPS. BPA encumbers firm capacity based
289 on the coincidental 1 in 10 peak forecast, less critical water forecasts of the federal
290 generation located in the Idaho BAA. Idaho Power then specifies what will be served
291 across La Grande W>E and BPA encumbers this amount for this path.

292 For BPA's flow-based paths, BPA accounts for NITS_F obligations with a combination of base
293 ETC and interim ETC calculations, as described further in this document.

294 **GF_F** is the firm capacity set aside for grandfathered contracts for energy and/or Transmission
295 Service, where executed prior to the effective date of a Transmission Service Provider's Open
296 Access Transmission Tariff or "safe harbor tariff."

297 The amount of GF_F BPA encumbers across its 1:1 paths is based on the terms of each
298 individual contract.

299 For BPA's flow-based paths, BPA accounts for GF_F obligations with base ETC calculations,
300 as described further in this document.

301 **PTP_F** is the firm capacity reserved for confirmed Point-to-Point Transmission Service.

302 In BPA's calculations for 1:1 paths, PTP_F is equal to the sum of the MW Demands of PTP_F
303 reservations or schedules.

304 For BPA's flow-based paths, BPA accounts for PTP_F obligations with a combination of base
305 ETC and interim ETC calculations, as described further in this document.

306 For Redirects from conditional short-term firm parent reservations, BPA's ETC accounts
307 for the parent reservation until the Redirect is confirmed on OASIS. Once the Redirect is
308 confirmed, BPA's ETC only accounts for the Redirect.

309 For Redirects from long-term firm parent reservations or unconditional short-term firm
310 parent reservations, BPA's ETC accounts for both the parent reservation and the Redirect
311 reservation until the Redirect itself is unconditional. Once the Redirect is unconditional,
312 BPA's ETC only accounts for the Redirect.

313 In some cases, BPA has PTP_F contracts that give customers the right to schedule between
314 multiple Points of Receipt (PORs) and Points of Delivery (PODs). However, the customer
315 can only schedule up to the MW amount specified in their contract. Multiple reservations
316 are created for these special cases to allow BPA to model each POR-to-POD combination.
317 The amount encumbered for these cases does not exceed the total PTP_F rights specified in
318 the contracts.

319 **ROR_F** is the firm capacity reserved for roll-over rights for contracts granting Transmission
320 Customers the right of first refusal to take or continue to take Transmission Service when the
321 Transmission Customer's Transmission Service contract expires or is eligible for renewal.

322 BPA assumes that all of its Transmission Service Agreements eligible to roll-over in the
323 future will be rolled over. If a Transmission Customer chooses not to exercise its roll-over
324 rights by the required deadline, BPA no longer encumbers capacity for roll-over rights for
325 that Transmission Customer.

326 **OS_F** is the firm capacity reserved for any other service(s), contract(s), or agreement(s) not
327 specified above using Firm Transmission Service as specified in the ATCID.

328 BPA has no OS_F and thus sets OS_F at zero for all of its paths for all time periods. All of
329 BPA's firm Transmission obligations are captured in the NITS_F, PTP_F, GF_F and ROR_F
330 components of the ETC_F algorithm.

331 Although BPA uses the above algorithm to calculate ETC_F for all of its paths, BPA's ETC_F
332 calculation methodology differs between its 1:1 and flow-based paths. For 1:1 paths, BPA
333 calculates ETC_F by assuming that 1 MW of reserved firm capacity equals 1 MW of ETC_F across
334 that path. The POR/POD combinations for 1:1 ATC paths that impact ETC_F can be found under
335 the Transmission Availability section of BPA's website. For the flow-based paths, BPA
336 calculates ETC_F by summing the base ETC from power-flow ETC studies with interim ETC_F
337 calculated using PTFs.

338 **Determining base ETC for Flow-Based Paths**

339 **Use of WECC Base Cases to Determine Base ETC**

340 BPA uses the WECC seasonal base cases and modifies them to calculate the base ETC
341 for its flow-based paths. BPA refers to these base cases as ETC Cases.

342 **Determining Base ETC for Heavy Load Base Cases**

343 BPA creates monthly heavy load ETC Cases to calculate base ETC values. BPA's ETC
344 cases are produced using a power flow model that computes how much power will
345 flow over each flow-based path for the assumed Load and generation levels for each
346 time period studied. Counterflows are inherently modeled in these base cases.

347 BPA uses the following assumptions to create heavy load ETC Cases for its base ETC
348 calculations:

349 **System topology:** Normal operating conditions are used. BPA uses the WECC Winter
350 seasonal case for its November through March ETC base cases, the WECC Spring
351 seasonal case for its April and May ETC base cases, and the WECC Summer seasonal
352 case for its June through October ETC base cases.

353 **Load:** BPA uses loads contained in the WECC seasonal base cases for the time periods
354 being studied, along with any updates to those loads BPA may have made after the
355 WECC base cases were received from WECC.

- 356 • **NITS_F, PTP_F and GF_F:** BPA assumes a 1-in-2 year monthly peak load forecast in all
357 its monthly ETC cases

358 **Generation:** For the generators in BPA's BAA or directly interconnected to BPA, BPA
359 uses the following generation assumptions:

360 **FCRPS:** For the FCRPS resources serving NITS_F, PTP_F, and GF_F Long-Term Reservations,
361 generation levels are set using a multiple-step process. For all time periods studied,
362 BPA uses the following process:

- 363 • The Columbia Generating Station is assumed to be on-line at full load in the ETC
364 cases. Generation levels at the Libby, Hungry Horse, Dworshak, and Albeni Falls
365 projects are based on the 90th percentile rate case generation values for these
366 projects. The generation levels at the Willamette Valley projects⁴ are set at a
367 monthly fleet-aggregate lower 10th percentile of Heavy Load Hour block
368 generation from the planning period of record and adjusted as needed to
369 accurately reflect operations that BPA knows are in place. **Nameplate Adjusted**

⁴ Willamette Valley projects include: Big Cliff, Cougar, Detroit, Dexter, Foster, Green Peter, Hills Creek, Lookout Point, and Lost Creek.

370 **Method:** When creating heavy load ETC Cases, generation levels for all other
371 federal hydro projects⁵ are set by first determining the nameplate for each project
372 and then adjusting such nameplates by outages forecasted for the particular
373 plants. Next in the month of August, the Lower Snake plants (Lower Granite,
374 Lower Monumental, Little Goose, and Ice Harbor) are capped at the observed
375 project outflow over the past ten Augusts. Then multiple generation scenarios are
376 modelled by stressing one of three different “zones” of Federal hydro resources to
377 the nameplate adjusted generation levels described above and scaling the
378 generation at the remaining Federal hydro projects to match the sum of the
379 demands for all contracts that call out non-specific Federal hydroelectric projects
380 as PORs after adjusting these demands for the portion served by Columbia
381 Generating Station, Libby, Hungry Horse, Dworshak, Albeni Falls, and the
382 Willamette Valley projects. The Federal PTP demands at each project are then
383 added to this result to obtain the final assumed generation level for each Federal
384 hydro project.

385 **Non-Federal Thermal Generators:** Non-federal thermal generators associated with
386 PTP_F, GF_F and NITS_F Transmission Service for BPA’s area and all adjacent TSP areas are
387 set at up to the contract Demand.

388 **Wind Generators:**

- 389 • **PTP_F:** Wind generators associated with PTP_F Long-Term Reservations are set at
390 the following depending on the scenarios being run:
 - 391 ○ Modeled on at 100 percent of the contract demand for the wind
392 generator; or
 - 393 ○ Modeled off
- 394 • **NITS_F:** The flow-based path impacts of wind generators identified as
395 designated network resources in NITS_F contracts or in the NT Resources
396 Memorandum of Agreement in BPA’s area are determined on a flow-based
397 path-by-flow-based path basis and set at the greater of the following:
 - 398 ○ The wind generators modeled on at the designated amount of the wind
399 generators; or,
 - 400 ○ The wind generators modeled off and replaced by increasing the FCRPS
401 generation level by the designated amount of the wind generators using
402 the Nameplate Adjusted Method for all ETC cases described above.Wind generators designated as network resources in NITS_F contracts for all
403 adjacent TSPs are modeled up to the designated amount.
- 404 • **GF_F:** BPA and all of BPA’s adjacent TSPs have no GF_F contracts for wind
405 generators.
406

⁵ Federal hydro projects include: Grand Coulee, Chief Joseph, Lower Granite, Lower Monumental, Little Goose, Ice Harbor, McNary, John Day, The Dalles, Bonneville.

407 **Behind the Meter Generators:** Non-federal resources that do not require
408 Transmission Service over the FCRTS and that are behind the meter are set up to
409 levels used in BPA’s process for power system planning studies.

410 **Mid-Columbia Hydro Projects:** Generation levels at the non-federal Mid-Columbia
411 hydro projects are set up to 90 percent of their historical output by season.

412 When creating heavy load ETC cases, if there is more generation than load plus
413 committed exports in the base case, BPA reduces excess generation to bring
414 generation and load into balance in order to solve the power flow model. This
415 generation reduction is done by reducing all excess generation pro rata, except for the
416 stressed FCRPS zone.

417 Starting with the November 2023 studies and going forward, BPA reduces all excess
418 generation by aggregating generators by fuel type, and scaling the aggregated fuel
419 type groups. Generation is then reduced based on how each generator participates as
420 part of the scaled generation fleet, with the exception of the stressed FCRPS zone.
421 Columbia Generation Station is always modeled on, in both methodologies.

422 When creating heavy load ETC cases, if there is more load and committed exports than
423 generation in the ETC base case, BPA reduces exports on the AC Intertie and Pacific DC
424 Intertie in the ETC base case. This is done to solve the power flow model.

425 **Sensitivity Studies for Heavy Load Base Cases**

426 In calculating its base ETC values, BPA runs ETC case scenarios for three different
427 sensitivities: the Canadian Entitlement Return (CER) obligation modeled on or off,
428 wind resources designated to serve PTP_F and NITS_F on or off, and stressing the three
429 different zones of the FCRPS.

430 For the FCRPS scenarios, the three “zones” that are stressed individually in the
431 scenarios are made up of the following projects: (i) Upper Columbia zone includes
432 Grand Coulee and Chief Joseph; (ii) Lower Snake zone includes Lower Monumental,
433 Lower Granite, Little Goose, and Ice Harbor; and (iii) Lower Columbia zone includes
434 McNary, John Day, The Dalles and Bonneville.

435 For the CER Scenarios, BPA models the FCRPS generators delivering or not delivering
436 energy to Canada in the amount specified in the Canadian Entitlement Agreement.

437 In the CER on scenarios, BPA models the exports to Canada at the Canadian
438 Entitlement Agreement contract level. The FCRPS generation is modeled using the
439 Nameplate Adjusted Method.

440 In the CER off scenarios, BPA models imports from Canada at the contract rights that
441 customers have across the Northern Intertie N>S. The FCRPS generation is also
442 modeled using the Nameplate Adjusted Method.

443 For the wind resource scenarios, see above for a description of the base ETC
444 assumptions for wind generators serving PTP_F and NITS_F.

445 Therefore, in its heavy load base ETC sensitivity analysis, BPA models the following 6
446 scenarios:

- 447 1. Wind modeled off/Upper Columbia stressed
- 448 2. Wind modeled off/Lower Snake stressed
- 449 3. Wind modeled off/Lower Columbia stressed
- 450 4. Wind modeled on/Upper Columbia stressed
- 451 5. Wind modeled on/Lower Snake stressed
- 452 6. Wind modeled on/Lower Columbia stressed

453 All scenarios are run with CER modeled on and off for all months.

454 BPA uses the highest base ETC value calculated from these scenarios in its firm ATC
455 calculations across the flow-based paths. BPA uses the lowest base ETC value from
456 these scenarios in its non-firm ATC calculations across the flow-based paths.

457 **Determining Base ETC and Sensitivities for Light Load Base Cases**

458 BPA uses the WECC Winter seasonal light load case as the starting point for its Winter
459 seasonal light load ETC base case. The ETC from this case is used as the base ETC for
460 the months of November through March.

461 BPA uses the WECC Summer seasonal light load case as the starting point for its
462 Summer light load ETC base case. The ETC from the Summer case is used as the base
463 ETC for the months of June through October.

464 If a WECC Spring seasonal light load case is available, BPA uses that case as the
465 starting point for its Spring seasonal light load ETC base case. The ETC from this case
466 is used as the base ETC for the months of April and May. If the WECC Spring seasonal
467 light load case is not available, the higher of the base ETCs from either the Winter or
468 Summer case are used as the base ETC for April and May.

469 BPA uses the following assumptions in light load ETC base cases:

- 470 a. System topology: Normal operating conditions are used.
- 471 b. Loads: Loads from the WECC light load cases are used. For Montana loads only,
472 BPA compares the loads in the WECC seasonal light load case with the seasonal
473 light loads supplied by Montana Power, and uses the lowest of the two values in
474 order to properly stress the light load case.
- 475 c. Generation: BPA uses generation assumptions from historical data. Canadian
476 Entitlement is modeled as delivering energy to Canada in the amount specified
477 in the Canadian Entitlement Agreement.

478 There are two sensitivity studies performed for the light load ETC base cases:

- 479 a. Federal generation east of the path is increased, and a corresponding amount
480 of federal generation west of the path is reduced
- 481 b. Federal generation east of the path is reduced, and a corresponding amount of
482 federal generation west of the path is increased

483 BPA uses the highest base ETC value calculated from these scenarios in its firm ATC
484 calculations across the flow-based paths where light load cases are utilized. BPA uses
485 the lowest base ETC value from these scenarios in its non-firm ATC calculations across
486 the flow-based paths where light load cases are utilized.

487 **Calculating Interim ETC_F for Flow-based Paths**

488 To calculate the impacts for all NITS_F and PTP_F reservations that were not modeled in the
489 base ETC cases, BPA uses PTDF analysis on the demand in each reservation. PTDF analysis
490 is the fraction of energy (expressed as a percentage or as a decimal) that will flow across
491 BPA's monitored flow-based paths as that energy is injected at a POR (or source) relative
492 to a slack bus, and withdrawn at a POD (or sink) relative to a slack bus, for each flow-
493 based path.

494 PTDF impacts are calculated as per BPA's Transmission Service Requests Evaluation
495 business practice. If a reservation's impact on a flow-based path is determined to be *de*
496 *minimis* per the Transmission Service Requests Evaluation business practice, then BPA
497 deems the impact of the reservation to be zero when calculating ETC_F used in the ATC_F
498 calculation.

499 The sum of these positive impacts is referred to as the interim ETC_F value, and is added to
500 the base ETC values to produce a final ETC_F value for each time period for each flow-
501 based path.

502 **Outages in PTDF Calculations**

503 BPA calculates PTDFs by adjusting the WECC base cases to include transmission
504 outages in BPA's outage system for BPA's area and any adjacent TSP areas.
505 Transmission outages for Transmission Lines, sections of Transmission Lines,
506 transformers and taps are used to set branches as *open* in the appropriate base
507 case for the hour being calculated.

508 When the Raver-Paul 500-kV line is out of service, the PTDFs that BPA calculates and
509 uses for the Raver-Paul path are based on the monitored lines for this path that are
510 outlined in Table 2. This allows BPA to properly manage the Raver-Paul path in this
511 outage situation.

512 **Outage Criteria in ETC Calculations**

513 BPA uses the outage planning timeline described in the "Outages" section. The
514 following criteria determine which outages are incorporated into BPA's hourly, daily
515 and monthly ETC calculations:

516 **Hourly ETC Calculations**

517 For its hourly ETC calculations, BPA uses hourly PTDFs published at least once per
518 day.

519 **Daily ETC Calculations**

520 For its daily ETC calculations, BPA uses the most recent PTDFs published for the
521 hour ending 11 of each day, since hour ending 11 tends to have the highest
522 coincidence of outages. Therefore all Transmission outages scheduled to occur
523 during the hour ending 11, regardless of the duration of the outage, impact daily
524 ETC calculations.

525 BPA includes Transmission outages in daily ETC calculations beyond the 10- to 16-
526 day planned outage study period if the outage is officially scheduled in BPA's
527 outage system.

528 **Monthly ETC Calculations**

529 For its monthly ETC calculations, BPA uses the most recent daily PTDFs published
530 for the first Tuesday of that month. BPA includes Transmission outages in monthly
531 ETC calculations beyond the 10- to 16-day planned outage study period if the
532 outage is officially scheduled in BPA's outage system.

533 **Source/POR and Sink/POD Identification and Mapping**

534 In the ETC components of its flow-based path ATC calculations, BPA accounts for
535 source and sink for Transmission Service through the following processes:

536 BPA maps the source/POR and sink/POD to the WECC base cases. In this mapping, BPA
537 has assigned network bus points that represent the primary interface for
538 Interconnection with specific generation projects, adjacent electrical Systems or
539 Load-serving entities and trading hubs. Some adjacent electrical Systems have
540 multiple Interconnection points deemed as PORs/sources or PODs/sinks. The mapping
541 of these points is published in the Transmission Service Contract Points list on BPA's
542 OASIS homepage.

543 BPA calculates weighted PTDFs for Sources/PORs as follows:

- 544 1. The PTDF weighting for the FCRPS/BPA Power PTDF varies by time period and path
545 based on stress scenarios. The PTDF weighting is derived from generation
546 forecasts of the federal resources, for calculations for the next hour through
547 approximately two weeks. Beyond this time frame, BPA derives the weighting of
548 the PTDF by applying the generation dispatch determined in the ETC Cases.
- 549 2. BPA derives the PTDF weighting for the Mid-Columbia bus point by applying the
550 generation dispatch determined in the ETC Cases.
- 551 3. BPA has grouped the generators in its adjacent BAAs based on the primary
552 interface between each BAA and the generation projects within that BAA
553 (excluding some remote generators that are scheduled via NERC e-Tag). These
554 groupings are assigned weighted PTDFs that represent how the generators
555 participate in the group and are used to evaluate transactions within and between
556 adjacent BAAs that do not include BPAT. BPA derives the PTDF weightings for
557 these points from BAA-provided generation estimates or by applying the generation
558 dispatch determined in the ETC Cases if generation estimates are not available. In

559 the ETC Cases, these generators are modeled up to the long-term firm
560 Transmission rights associated with the generators.

561 BPA calculates weighted PTDFs for Sinks/PODs as follows:

- 562 1. BPA has weighted PTDFs for loads in its adjacent BAAs based on the primary
563 interface between each BAA and the load within that BAA. The weighting is based
564 on how the load is distributed in the BAA.
- 565 2. BPA calculates a weighted PTDF to account for unscheduled Network Integration
566 Transmission Service loads in BPA's BAA that are served from the FCRPS. The
567 weighting is based on the individual load forecasts for the time period being
568 calculated.
- 569 3. BPA calculates a weighted load for all of the BPA Power Services customers that
570 are served via Network Integration Transmission Service agreements. The
571 weighting is based on the individual load forecasts for the time period being
572 calculated.
- 573 4. BPA calculates a weighted load for PNGC Power, which is a Joint Operating Entity
574 made up of several cooperative utilities. The weighting is based on the individual
575 load forecasts for the time period being calculated.

576 BPA calculates one weighted PTDF that applies to the following Source/POR and
577 Sink/POD:

- 578 1. BPA calculates a weighed PTDF for the Western Energy Imbalance Market. This
579 weighting is based on the percentage of Automatic Generation Control response
580 (which could be zero) carried by each plant in the FCRPS.

581 **Calculating Firm Available Transfer Capability (ATC_F)**

582 When calculating ATC_F for its paths for all time periods, BPA uses the following algorithm:

$$583 \quad \text{ATC}_F = \text{TTC} - \text{ETC}_F - \text{CBM} - \text{TRM} + \text{Postbacks}_F + \text{Counterflows}_F$$

584 **Where:**

585 ATC_F is the firm Available Transfer Capability for the ATC path for that period for which ATC_F
586 is being calculated.

587 TTC is the Total Transfer Capability of the ATC path for that period.

588 ETC_F is the sum of existing firm commitments for the ATC path as specified in WEQ-023 during
589 that period for which ATC_F is being calculated.

590 For ATC_F calculations for all time periods, BPA divides ETC_F into the following variables
591 within its ATC software:

$$592 \quad \text{ETC}_F = \text{LRES} + \text{SRES} + \text{LETC} - \text{SADJ/ETC Adjustments}$$

593 **Where:**

594 **LRES** is the sum of positive impacts of BPA’s Long-Term Reservations.

595 **SRES** is the sum of positive impacts of BPA’s Short-Term Reservations.

596 **LETC** is used to ensure that the amount of $NITS_F$, GF_F , PTP_F and ROR_F capacity BPA sets
597 aside in the **LRES** variable for contracts where BPA gives customers the right to schedule
598 the capacity reserved between multiple PORs and PODs does not exceed the total capacity
599 specified in those contracts.

600 **LETC** is also used to align the **ETC** calculated in the power flow base case with additional
601 **PTDF** calculations in order to balance to the standard **OATI** calculation. This adjustment is
602 derived by comparing two values: a) the impacts of the confirmed PTP_F , GF_F , $NITS_F$ and
603 ROR_F Long-Term Reservations derived from the base **ETC** Cases and b) the impacts of the
604 same reservations calculated using **PTDF** Analysis for each flow-based path. The
605 adjustment for each flow-based path is equal to the difference of these two values.
606 Conditional firm reservations are not included in the **ETC** Cases and therefore are also not
607 included in this comparison.

608 **SADJ/ETC Adjustments** is the variable BPA uses to make adjustments to ETC_F not
609 captured in **LRES** or **SRES**.

610 BPA applies one such adjustment to allow for deferral competitions, as required in Section
611 17.7 of BPA’s **OATT**. When a deferral reservation is confirmed, BPA applies an **SADJ/ETC**
612 Adjustment to hold out capacity for the time period deferred, starting at the latter of five
613 months out or the service commencement date of the original reservation, to allow for a
614 competition. At four months out, if no competition is identified, the **SADJ/ETC**
615 Adjustment is modified to release the capacity for the fourth month out.

616 BPA uses a **SADJ/ETC** Adjustment to account for a portion of the firm **TRM** that BPA
617 applies on the **NI S>N**.

618 BPA also uses **SADJ/ETC** Adjustments to ensure accurate accounting of ETC_F . These
619 adjustments may be performed to account for situations such as data modeling
620 corrections, and are noted in the descriptions of the adjustments.

621 The following diagram illustrates how the variables in BPA’s **ATC** software correspond to
622 the variables in the ETC_F algorithm.

ETC_F =	NITS_F	+	GF_F	+	PTP_F	+	ROR_F
	↓		↓		↓		↓
	LRES		LRES		LRES		LRES
	+				+		
	SRES				SRES		
	+		+		+		+
	LETC		LETC		LETC		LETC
	-		-		-		-
	SADJ/ETC		SADJ/ETC		SADJ/ETC		SADJ/ETC
	Adjustments		Adjustments		Adjustments		Adjustments

623 **CBM** is the Capacity Benefit Margin for the ATC path during that period.

624 BPA does not maintain CBM and thus sets CBM at zero for all of its paths for all time
625 periods.

626 **TRM** is the Transmission Reliability Margin for the ATC path during that period.

627 The description of how BPA implements TRM can be found in BPA's TRMID, which is posted
628 on BPAs website.

629 **Postbacks_F** are changes to firm Available Transfer Capability due to a change in the use of
630 Transmission Service, as defined in WEQ-023.

631 BPA automatically recalculates ETC_F to account for changes to Transmission Service
632 Requests (such as request types of Recall and Redirect and annulments). Since these
633 types of changes to Transmission Service Requests are captured in ETC_F, BPA treats
634 Postbacks_F as zero for all time periods when calculating ATC_F.

635 **Counterflows_F** are adjustments to firm Available Transfer Capability as determined by the
636 Transmission Service Provider and specified in their ATCID.

637 BPA does not include confirmed Transmission reservations, expected interchange or
638 internal flow counter to the direction of the path being calculated in its ATC_F calculations.
639 BPA's rationale is that it does not want to offer firm ATC due to counterflow that may not
640 be scheduled as this could lead to curtailments of Firm Transmission Service in the Real-
641 time horizon. Therefore BPA sets Counterflows_F at zero for all of its paths for all time
642 periods.

643 For flow-based paths, counterflows are automatically modeled in the base ETC cases. In
644 instances where the power flow study results in a negative base ETC value, BPA uses zero
645 as the base ETC for purposes of calculating ATC_F. This is done to ensure that BPA does not
646 make capacity available as a result of counterflows that may or may not materialize in
647 real-time.

648 **Calculating Non-Firm Transmission Service for BPA's Paths**

649 BPA calculates ETC_{NF} and ATC_{NF} for each of its six non-firm Transmission products. The six
650 non-firm products are: Secondary Network (NITS_{NF6}), Monthly Non-Firm PTP (PTP_{NF5}), Weekly
651 Non-Firm PTP (PTP_{NF4}), Daily Non-Firm PTP (PTP_{NF3}), Hourly Non-Firm PTP (PTP_{NF2}) and
652 Secondary Non-Firm Hourly PTP (PTP_{NF1}).

653 **Calculating Non-Firm Existing Transmission Commitments (ETC_{NF})**

654 BPA calculates ETC_{NF} for all time periods and paths using the following algorithm:

$$655 \text{ETC}_{NF} = \text{NITS}_{NF} + \text{GE}_{NF} + \text{PTP}_{NF} + \text{OS}_{NF}$$

656 ETC_{NF} is calculated for each of BPA's six non-firm Transmission products as follows:

- 657 1. ETC_{NF6}: includes the NITS_{NF6} transmission product
- 658 2. ETC_{NF5}: includes the NITS_{NF6} and PTP_{NF5} transmission products

- 659 3. ETC_{NF4}: includes the NITS_{NF6}, PTP_{NF5} and PTP_{NF4} transmission products
- 660 4. ETC_{NF3}: includes the NITS_{NF6}, PTP_{NF5}, PTP_{NF4}, and PTP_{NF3} transmission products
- 661 5. ETC_{NF2}: includes the NITS_{NF6}, PTP_{NF5}, PTP_{NF4}, PTP_{NF3} and PTP_{NF2} transmission products
- 662 6. ETC_{NF1}: includes the NITS_{NF6}, PTP_{NF5}, PTP_{NF4}, PTP_{NF3}, PTP_{NF2} and PTP_{NF1} transmission products

663 **Where:**

664 ETC_{NF} is the non-firm ETC for the ATC path.

665 NITS_{NF} is the non-firm capacity reserved for Secondary Network Transmission Service, to
666 include losses, and Load growth not otherwise included in Transmission Reliability Margin or
667 Capacity Benefit Margin.

668 In BPA's calculations, this is comprised of the NITS_{NF6} Transmission product. BPA's NITS_{NF6}
669 calculation does not include losses or Load growth, since losses and Load growth are
670 already encumbered as firm capacity in NITS_F.

671 GF_{NF} is the non-firm capacity set aside for grandfathered contracts for energy and/or
672 Transmission Service, where executed prior to the effective date of a Transmission Service
673 Provider's Open Access Transmission Tariff or "safe harbor tariff."

674 BPA does not have any grandfathered non-firm Transmission Service obligations and thus
675 sets GF_{NF} at zero for all of its paths for all time periods.

676 PTP_{NF} is non-firm capacity reserved for confirmed Point-to-Point Transmission Service.

677 Depending on the ETC_{NF} being calculated, PTP_{NF} will include the PTP_{NF5}, PTP_{NF4}, PTP_{NF3},
678 PTP_{NF2} and PTP_{NF1} Transmission products.

679 OS_{NF} is the non-firm capacity reserved for any other service(s), contract(s), or agreement(s)
680 not specified above using non-firm transmission service as specified in the ATCID.

681 BPA has no OS_{NF} and thus sets OS_{NF} at zero for all of its paths for all time periods.

682 ETC_{NF} for 1:1 paths is calculated by assuming that 1 MW of reserved and/or scheduled capacity
683 results in 1 MW of impact across the 1:1 path. The POR/POD combinations for 1:1 ATC paths
684 that impact ETC_{NF} can be found under the Transmission Availability section of BPA's website.

685 When calculating ETC_{NF} for flow-based paths, BPA sums the positive impacts of reservations
686 and/or schedules as determined by PTDf analysis, per BPA's Transmission Service Requests
687 Evaluation business practice. The treatment of *de minimis* impacts in ETC_{NF} is covered within
688 the Calculating Non-Firm Available Transfer Capability section below.

689 **Calculating Non-Firm Available Transfer Capability (ATC_{NF})**

690 BPA calculates ATC_{NF} for its paths for two horizons: Real-time and Beyond Real-time. The
691 Real-time horizon begins at 10 p.m. each day for the 24 hours in the next day. The Beyond
692 Real-time horizon includes hourly for the hours after those included in the Real-time period
693 as well as daily and monthly calculations.

694 BPA calculates ATC_{NF} for all time periods and paths using the following algorithm:

695
$$ATC_{NF} = TTC - ETC_F - ETC_{NF} - CBM_S - TRM_U + Postbacks_{NF} + Counterflows_{NF}$$

696 ATC_{NF} is calculated for each of BPA's six non-firm Transmission products as follows:

697 1. $ATC_{NF6} = TTC - ETC_F - ETC_{NF6} - CBM_S - TRM_U + Postbacks_{SNF} + Counterflows_{SNF}$

698 2. $ATC_{NF5} = TTC - ETC_F - ETC_{NF5} - CBM_S - TRM_U + Postbacks_{SNF} + Counterflows_{SNF}$

699 3. $ATC_{NF4} = TTC - ETC_F - ETC_{NF4} - CBM_S - TRM_U + Postbacks_{SNF} + Counterflows_{SNF}$

700 4. $ATC_{NF3} = TTC - ETC_F - ETC_{NF3} - CBM_S - TRM_U + Postbacks_{SNF} + Counterflows_{SNF}$

701 5. $ATC_{NF2} = TTC - ETC_F - ETC_{NF2} - CBM_S - TRM_U + Postbacks_{SNF} + Counterflows_{SNF}$

702 6. $ATC_{NF1} = TTC - ETC_F - ETC_{NF1} - CBM_S - TRM_U + Postbacks_{SNF} + Counterflows_{SNF}$

703 Table 3 outlines the differences in how the ATC_{NF} algorithm components are calculated
704 between the Beyond Real-time and Real-time time horizons.

705

Table 3, ATC_{NF} Calculation for Beyond Real-Time and Real-Time Horizons

Algorithm Component	Beyond Real-time	Real-time
TTC	As described in TTC section in the ATCID	Same
ETC _F	Calculated using reservations and base ETC cases for flow-based paths <ul style="list-style-type: none"> • <i>De minimis</i> impacts are treated as zero in ETC_F 	Calculated using schedules <ul style="list-style-type: none"> • <i>De minimis</i> impacts are included in ETC_F
ETC _{NF}	Calculated using reservations <ul style="list-style-type: none"> • <i>De minimis</i> impacts are treated as zero in ETC_{NF} 	Calculated using reservations until scheduled, then calculated using schedules <ul style="list-style-type: none"> • <i>De minimis</i> impacts are included in ETC_{NF} for both reservations and schedules
CBM _S	N/A	N/A
TRM _U	As described in the TRMID	Same
Postback _{S_{NF}}	Zero since ETC _{NF} is recalculated to capture changes to the Transmission Service Requests	Zero since ETC _{NF} is recalculated to capture changes to the Transmission Service Requests and/or schedules, with the exception of AC N>S
Counterflows _{NF}	Included with schedules	Same

706 **Where:**

707 **ATC_{NF}** is the non-firm Available Transfer Capability for the ATC path for that period for which
 708 ATC_{NF} is being calculated.

709 BPA calculates six ATC_{NF} values as described above.

710 **TTC** is the Total Transfer Capability of the ATC path for that period.

711 **ETC_F** is the sum of existing firm commitments for the ATC path as specified in WEQ-023 during
 712 that period for which ATC_{NF} is being calculated.

713 The section below outlines how BPA calculates ETC_F for all of its paths for the beyond
 714 Real-time and the Real-time horizons.

715 **ETC_F for the Beyond Real-Time Horizon**

716 Reservations, and base ETC cases for flow-based paths, are used to calculate ETC_F for the
 717 Beyond Real-time horizon. When calculating ETC_F for this horizon, *de minimis* impacts of
 718 reservations across flow-based paths are deemed to be zero.

719 For ATC_{NF} calculations for the beyond Real-time horizon, BPA utilizes the following
 720 variables within its ATC software to calculate ETC_F:

721 $ETC_F = LRES + SRES - SADJ/ETC \text{ Adjustments} + NFETC$

722 **Where:**

723 **LRES** is the sum of positive impacts of BPA’s Long-Term Reservations.

724 **SRES** is the sum of positive impacts of BPA’s Short-Term Reservations.

725 **SADJ/ETC Adjustments** is the variable used to make adjustments to ETC_F not captured
726 in LRES or SRES.

727 BPA applies one such adjustment to allow for deferral competitions, as required in
728 Section 17.7 of BPA’s OATT. When a deferral reservation is confirmed, BPA applies a
729 SADJ/ETC Adjustment to hold out capacity for the time period deferred, starting at
730 the latter of five months out or the service commencement date of the original
731 reservation, to allow for a competition. At four months out, if no competition is
732 identified, the SADJ/ETC Adjustment is modified to add back capacity for the fourth
733 month out.

734 BPA uses SADJ/ETC Adjustments to ensure accurate accounting of ETC_F . These
735 adjustments may be performed to account for situations such as data modeling
736 corrections, and are noted in the descriptions of the adjustments.

737 **NFETC** is used to ensure that the amount of $NITS_F$, GF_F , PTP_F and ROR_F capacity BPA
738 sets aside in the LRES variable for contracts where BPA gives customers the right to
739 schedule the capacity reserved between multiple PORs and PODs does not exceed the
740 total capacity specified in those contracts.

741 **NFETC** is also used to align the ETC calculated in the power flow base case along with
742 additional PTDF calculations in order to balance to the standard OATI calculation.

743 This adjustment is derived by comparing two values: a) the impacts of the PTP_F , GF_F
744 and $NITS_F$ Long-Term Reservations derived from the base ETC Cases and b) the impacts
745 of the same reservations calculated using PTDF Analysis for each flow-based path. The
746 adjustment for each flow-based path is equal to the difference of these two values.
747 Conditional firm reservations are not included in the ETC Cases and therefore are also
748 not included in this comparison.

749 The following diagram illustrates how the variables in BPA’s ATC software correspond
750 to the variables in the ETC_F algorithm for the Beyond Real-time horizon.

ETC_F =	NITS_F	+	GF_F	+	PTP_F	+	ROR_F
	↓		↓		↓		↓
	LRES		LRES		LRES		LRES
	+				+		
	SRES				SRES		
	+		+		+		+
	NFETC		NFETC		NFETC		NFETC
	-		-		-		-
	SADJ/ETC Adjustments		SADJ/ETC Adjustments		SADJ/ETC Adjustments		SADJ/ETC Adjustments

751 **ETC_F for the Real-Time Horizon**
 752 For ATC_{NF} calculations for the Real-time horizon, BPA divides ETC_F into the following
 753 variables within its ATC software:

754
$$\text{ETC}_F = \text{SCH}^{+7} + \text{ASC}^{+7} + \text{RADJ/ETC Adjustment}$$

755 Schedules are used to calculate ETC_F for the Real-time horizon. When calculating ETC_F for
 756 this horizon, *de minimis* impacts of schedules across flow-based paths are included in
 757 ETC_F.

758 **Where:**

759 **SCH⁺⁷** is the sum of the positive impacts of schedules that reference confirmed NITS_F,
 760 GF_F and PTP_F reservations for the ATC path for that period. The energy profile of the
 761 schedule is used except for the schedule types of Dynamic, Capacity and Pseudo-tie.

762 **ASC⁺⁷** is the sum of the positive impacts of dynamic schedules that reference
 763 confirmed NITS_F, GF_F and PTP_F reservations for the ATC path for that period. The
 764 transmission profile of the schedule is used for the schedule types of Dynamic,
 765 Capacity and Pseudo-tie.

766 **RADJ/ETC Adjustment:** BPA uses RADJ/ETC adjustments to ensure accurate
 767 accounting of ETC_F. These adjustments may be performed to account for situations
 768 such as data modeling corrections.

769 The following diagram illustrates how the variables in BPA’s ATC software correspond
 770 to the variables in the ETC_F algorithm for the Real-time horizon. ROR_F is not included
 771 in ETC_F for the Real-time horizon because ROR_F is not relevant for the Real-time
 772 horizon.

ETC_F =	NITS_F	+	GF_F	+	PTP_F
	↓		↓		↓
	SCH⁺⁷		SCH⁺⁷		SCH⁺⁷
	+		+		+
	ASC⁺⁷		ASC⁺⁷		ASC⁺⁷
	+		+		+
	RADJ/ETC Adjustment		RADJ/ETC Adjustment		RADJ/ETC Adjustment

773 **ETC_{NF}** is the sum of existing non-firm commitments for the ATC path as specified in WEQ-023
 774 during that period for which ATC_{NF} is being calculated.

775 The section below outlines how BPA calculates ETC_{NF} for all of its paths for the beyond
 776 Real-time and the Real-time horizons.

777 **ETC_{NF} for the Beyond Real-Time Horizon**

778 For ATC_{NF} calculations for the beyond Real-time horizon, ETC_{NF} is reflected as the
 779 following variable within BPA’s ATC software:

780 $ETC_{NF} = RRES_{6,5,4,3,2,1}$

781 Reservations are used to calculate ETC_{NF} for the Beyond Real-time horizon. When
782 calculating ETC_{NF} for this horizon, *de minimis* impacts of reservations across flow-based
783 paths are deemed to be zero.

784 **Where:**

785 $RRES_{6,5,4,3,2,1}$ is the sum of the positive impacts of all confirmed $NITS_{NF6}$, PTP_{NF5} , PTP_{NF4} ,
786 PTP_{NF3} , PTP_{NF2} and PTP_{NF1} reservations.

787 The following diagram illustrates how the variables in BPA's ATC software correspond
788 to the variables in the ETC_{NF} algorithm for the Beyond Real-time horizon.

$ETC_{NF} =$	$NITS_{NF}$	+	PTP_{NF}
	↓		↓
	$RRES_6$		$RRES_{5,4,3,2,1}$

789 **ETC_{NF} for the Real-Time Horizon**

790 For ATC_{NF} calculations in the Real-time horizon, ETC_{NF} is reflected as the following
791 variables within BPA's ATC software:

792 $ETC_{NF} = SCH^+_{6,5,4,3,2,1} + ASC^+_{6,5,4,3,2,1}$

793 To calculate ETC_{NF} for the Real-time horizon, reservations are used until schedules are
794 received, and then schedules are used. When calculating ETC_{NF} for this horizon, *de*
795 *minimis* impacts across flow-based paths are included in ETC_{NF} , regardless of whether the
796 reservation or schedule is being used in the calculation.


797 **Where:**

798 $SCH^+_{6,5,4,3,2,1}$ is the sum of the positive impacts of schedules referenced to confirmed
799 $NITS_{NF6}$, PTP_{NF5} , PTP_{NF4} , PTP_{NF3} , PTP_{NF2} and PTP_{NF1} reservations, plus the sum of the
800 positive impacts of pending and confirmed $NITS_{NF6}$, PTP_{NF5} , PTP_{NF4} , PTP_{NF3} , PTP_{NF2} and
801 PTP_{NF1} reservations that have not yet been scheduled. Once these reservations are
802 scheduled, the schedule is used for ETC_{NF} , thereby adding back the difference
803 between the reservation and schedule amounts to ATC_{NF} . The energy profile of the
804 schedule is used except for the schedule types of Dynamic, Capacity and Pseudo-tie.

805 $ASC^+_{6,5,4,3,2,1}$ is the sum of positive impacts of dynamic schedules referenced to
806 confirmed $NITS_{NF6}$, PTP_{NF5} , PTP_{NF4} , PTP_{NF3} , PTP_{NF2} and PTP_{NF1} reservations, plus the sum of
807 the positive impacts of pending and confirmed $NITS_{NF6}$, PTP_{NF5} , PTP_{NF4} , PTP_{NF3} , PTP_{NF2} and
808 PTP_{NF1} reservations that have not yet been scheduled. Once these reservations are
809 scheduled, the schedule is used for ETC_{NF} , thereby adding back the difference
810 between the reservation and schedule amounts to ATC_{NF} . The transmission profile of
811 the schedule is used for the schedule types of Dynamic, Capacity and Pseudo-tie.

812 The following diagram illustrates how the variables in BPA’s ATC software correspond
 813 to the variables in the ETC_{NF} algorithm for the Real-time horizon.

814



815 **CBMs** is the Capacity Benefit Margin for the ATC path that has been scheduled during that
 816 period.

817 BPA does not maintain CBM and thus sets CBMs at zero for all of its paths for all time
 818 periods.

819 **TRM_u** is the Transmission Reliability Margin for the ATC path that has not been released for
 820 sale (unreleased) as non-firm capacity by the Transmission Service Provider during that
 821 period.

822 The description of how BPA implements TRM can be found in BPA’s TRMID, which is posted
 823 on BPAs website.

824 **Postbacks_{NF}** are changes to non-firm Available Transfer Capability due to a change in the use
 825 of Transmission Service, as defined in WEQ-023.

826 The section below outlines how BPA calculates Postbacks_{NF} for all of its paths for the
 827 beyond Real-time and the Real-time horizons.

828 **Postbacks_{NF} for the Beyond Real-time horizon**

829 BPA automatically recalculates ETC_{NF} to account for changes to Transmission Service
 830 Requests (such as request types of Recall and annulments) for the Beyond Real-time
 831 horizon. Since these types of changes to Transmission Service Requests are captured in
 832 ETC_{NF}, BPA treats Postbacks_{NF} as zero for this horizon.

833 **Postbacks_{NF} for the Real-time Horizon**

834 BPA automatically recalculates ETC_{NF} to account for changes to Transmission Service
 835 Requests (such as request types of Recall and annulments) and/or schedules for the Real-
 836 time Horizon. Since these types of changes to Transmission Service Requests and/or
 837 schedules are captured in ETC_{NF}, BPA treats Postbacks_{NF} as zero for this horizon for all
 838 paths with the exception of AC N>S.

839 For ATC_{NF} calculations for the AC N>S path in the Real-time horizon, BPA uses a
840 Postbacks_{NF}, expressed as RADI/ETC. For its hourly AC N>S non-firm calculations, BPA
841 posts back any unused share of non-firm capacity that is available to BPA by capacity
842 ownership and other Agreements for the AC N>S, if needed to prevent Curtailments.

843 **Counterflows_{NF}** are adjustments to non-firm Available Transfer Capability as determined by
844 the Transmission Service Provider and specified in its ATCID.

845 Since a schedule provides assurance that the transaction will flow, all counterflows
846 resulting from firm and non-firm Transmission schedules, excluding tag types dynamic,
847 pseudo and capacity, are added back to ATC_{NF} in the Counterflows_{NF} component.

848 In BPA's ATC_{NF} calculations, Counterflows_{NF} is expressed as $SCH^{-7,6,5,4,3,2,1}$, which is the sum
849 of schedules flowing in the direction counter to the direction of the path.

850 Counterflows are modeled in the ETC Cases used to determine ETC_F for BPA's flow-based
851 paths. In instances where the power flow study results in a negative base ETC value, BPA
852 uses zero as the base ETC for purposes of calculating ATC_{NF} . This is done to ensure that
853 BPA does not make capacity available as a result of counterflows that may or may not
854 materialize in real-time

855 In some cases, the amount of Counterflows_{NF} exceeds the sum of the ETC_F and ETC_{NF} ,
856 which, when added to TTC, results in ATC_{NF} greater than TTC.

857 Note: The variable RADI/ETC is also used to respond to a BPA dispatcher order to change ATC
858 values by a specified amount and thereby reduce schedules in-hour when the flow exceeds
859 the TTC.

860 **Adjustments to Flow-based Path ATC Values**

861 There may be instances where BPA needs to perform testing in the production environment of
862 BPA's ATC software, or add flow-based paths in advance of their effective date. In these
863 instances, BPA will adjust its ATC values across the flow-based paths to ensure that
864 Transmission Service Requests are not refused due to lack of ATC across the flow-based paths.
865 BPA will notify customers prior to events that require these types of adjustments to ATC
866 values.

867 **VIII. Responding to Methodology/Documentation Clarifications and/or** 868 **Data Requests**

869 BPA will respond to all written requests for clarification of its TTC/TFC methodology, ATCID,
870 CBMID, or TRMID from any registered entity that demonstrates a reliability need within 45
871 days of receiving the written request. Methodology and/or documentation clarification
872 requests should be sent to nercatstandards@bpa.gov with "Methodology/Documentation
873 Clarification" in the subject line.

874 BPA will respond to written data requests from any Transmission Service Provider or
875 Transmission Operator, solely for use in the requestor’s ATC or AFC calculations, within 45
876 calendar days of receiving the written request. For a Transmission Service Provider or
877 Transmission Operator to officially request data to use in ATC or AFC calculations, the
878 requestor must fill out the **Data Request Form** found on BPA’s ATC Methodology website.
879 The completed request form must be sent to nercatcstandards@bpa.gov with “**Data Request**
880 **Form**” in the subject line.

881 **IX. ATCID Revisions**

882 BPA posts this ATCID in accordance with NAESB Business Practice Standard WEQ-001.