

**B O N N E V I L L E**  
**P O W E R   A D M I N I S T R A T I O N**



**Available Transfer Capability  
Implementation Document  
(North American Energy Standards Board WEQ-023)**

**Bonneville Power Administration  
Transmission Services**

**Effective Date: May 15, 2024**

---

## Contents

I. Purpose .....	1
II. Definitions .....	1
III. Overview .....	2
<b>Methodology Selected</b> .....	2
Rated System Path Methodology, WEQ-023-2.2 .....	2
<b>ATC Calculations</b> .....	2
ATC Calculation Periods .....	2
Frequency of ATC Recalculation.....	2
IV. Allocation Processes .....	2
V. Outages .....	3
<b>Outage Planning</b> .....	3
<b>Outage Criteria for TTC Calculations</b> .....	3
VI. Priorities Used to Set TTC .....	4
VII. Rated System Path Methodology for BPA’s Paths.....	5
<b>BPA’s Paths</b> .....	5
<b>Calculating TTC</b> .....	9
Data and Assumptions.....	9
Process to Determine TTC.....	10
<b>Calculating Firm Transmission Service for Paths</b> .....	12
Calculating Firm Existing Transmission Commitments (ETC <sub>F</sub> ) .....	12
Determining base ETC for Flow-Based Paths.....	14
Calculating Interim ETC <sub>F</sub> for Flow-based Paths.....	18
Calculating Firm Available Transfer Capability (ATC <sub>F</sub> ) .....	20
<b>Calculating Non-Firm Transmission Service for BPA’s Paths</b> .....	23
Calculating Non-Firm Existing Transmission Commitments (ETC <sub>NF</sub> ) .....	23
Calculating Non-Firm Available Transfer Capability (ATC <sub>NF</sub> ) .....	24
<b>Adjustments to Flow-based Path ATC Values</b> .....	31
VIII. Responding to Methodology/Documentation Clarifications and/or Data Requests ....	31
IX. ATCID Revisions .....	31

---

## 3 I. Purpose

4 This Available Transfer Capability Implementation Document (ATCID) addresses all of the  
5 requirements of North American Energy Standards Board (NAESB) Wholesale Electric Quadrant  
6 business practice standard 023 (WEQ-023), and includes BPA's Postback Methodology.

7 This ATCID only applies to ATC calculations through month 13.

---

## 8 II. Definitions

9 All capitalized terms used in this ATCID are either contained in NERC's Glossary of Terms,  
10 NAESB WEQ-000, or are defined in this ATCID.

11 Defined terms specific to BPA include:

- 12 • **Federal Columbia River Power System (FCRPS):** The Transmission System  
13 constructed and operated by BPA and the 31 federally-constructed hydroelectric dams<sup>1</sup>  
14 on the Columbia and Snake Rivers, and the Columbia Generating Station nuclear plant.  
15 Each entity is separately managed and financed, but the facilities are operated as an  
16 integrated power System.
- 17 • **Federal Columbia River Transmission System (FCRTS):** The FCRTS is comprised of  
18 BPA's main grid network Facilities (Network), Interconnections with other  
19 Transmission Systems (External Interconnections<sup>2</sup>), Interties,<sup>3</sup> delivery Facilities,  
20 subgrid Facilities, and generation Interconnection Facilities within the Pacific  
21 Northwest region and with western Canada and California.
- 22 • **Long-Term Reservation:** a confirmed reservation that has duration greater than or  
23 equal to 365 days
- 24 • **Short-Term Reservation:** a confirmed reservation that has duration less than 365  
25 days

---

<sup>1</sup> Albeni Falls, Anderson Ranch, Big Cliff, Black Canyon, Boise River Diversion, Bonneville, Chandler, Chief Joseph, Cougar, Detroit, Dexter, Dworshak, Foster, Grand Coulee, Green Peter, Green Springs, Hills Creek, Hungry Horse, Ice Harbor, John Day, Libby, Little Goose, Lookout Point, Lost Creek, Lower Granite, Lower Monumental, McNary, Minidoka, Palisades, Roza and The Dalles

<sup>2</sup> Northern Intertie, Reno-Alturas, West of Hatwai, West of Garrison and La Grande paths.

<sup>3</sup> AC Intertie (NWACI), Pacific DC Intertie (PDCI), and Montana Intertie.

---

## 26 III. Overview

---

27 BPA owns and provides Transmission Service over the FCRTS. BPA is registered with NERC as a  
28 Transmission Operator (TOP) and Transmission Service Provider (TSP), among other  
29 registrations.

### 30 Methodology Selected

#### 31 Rated System Path Methodology, WEQ-023-2.2

32 BPA has elected to use the Rated System Path Methodology to calculate Total Transfer  
33 Capability (TTC) and Available Transfer Capability (ATC) for all its paths. The description  
34 of how BPA implements this methodology for these paths is included in this ATCID.

### 35 ATC Calculations

#### 36 ATC Calculation Periods

37 BPA calculates ATC values using the Rated System Path Methodology for the following time  
38 periods:

- 39 • Hourly values for up to 168 hours. The next hour may be calculated in subhourly  
40 intervals, with the most limiting subhourly ATC value being the hourly value.
- 41 • Daily values for day 3 through day 90. For days 3 to 7 (up to hour 168), the daily ATC  
42 value is the most limiting hourly ATC value for that day.
- 43 • Monthly values for month 2 through month 13. For months 2 and 3 (up to day 90), the  
44 monthly ATC value is the most limiting daily ATC value for that month.

#### 45 Frequency of ATC Recalculation

46 BPA recalculates ATC on the following frequency, even if the calculated values  
47 identified in the ATC equation are unchanged:

- 48 • Hourly, at least once per hour
- 49 • Daily, at least once per day
- 50 • Monthly, at least once per day

51 BPA may recalculate ATC values more frequently due to changes in Total Transfer  
52 Capability (TTC), Power Transfer Distribution Factors (PTDFs), system issues or as deemed  
53 necessary.

---

## 54 IV. Allocation Processes

---

55 BPA allocates transfer capability among multiple owners or users of its 1:1 and flow-based  
56 paths.

57 **Allocations - TTC:**

58 For paths where allocation agreements exist, BPA allocates TTC according to the  
59 contractual rights of the various owners as defined in the agreements.

60 Allocation agreements do not exist for two of BPA's flow-based paths that have multiple  
61 owners: Columbia Injection N>S and Wanapum Injection N>S. For Columbia Injection N>S  
62 and Wanapum Injection N>S, BPA determines its share of TTC based on BPA-owned  
63 transmission lines that make up these paths when all lines are in service. During outage  
64 conditions, individual allocations exist for the loss of each transmission line in the line  
65 definitions for these paths.

66 **Allocations - base ETC:**

67 BPA allocates base ETC among some of its shared flow-based paths. To allocate base ETC  
68 for South of Allston N>S, BPA uses the contractual rights defined in the South of Allston  
69 allocation agreement. To allocate base ETC for the Columbia Injection N>S, Wanapum  
70 Injection N>S, and Cross Cascades North E>W paths, BPA only models the BPA-owned  
71 transmission lines that make up these paths in the base ETC cases. BPA does not allocate  
72 base ETC across any other shared flow-based paths.

73 **Allocations - PTDFs:**

74 BPA calculates PTDFs based on the full path definition of all paths with the exception of  
75 Columbia Injection N>S, Wanapum Injection N>S and Cross Cascades North E>W. For these  
76 three paths, BPA calculates PTDFs based on the BPA-owned transmission lines that make  
77 up these paths.

---

78 **V. Outages**

---

79 Outages from all TSPs that are internal or adjacent to BPA's Balancing Authority Area (BAA)  
80 can be mapped to the WECC base cases.

81 **Outage Planning**

82 Outage plans and the policy are posted to the Outage Plans website at: [Outage Coordination -  
83 Bonneville Power Administration \(bpa.gov\)](http://www.bpa.gov/OutageCoordination)

84 **Outage Criteria for TTC Calculations**

85 BPA incorporates outages into the TTC calculations after they have been studied by BPA or  
86 provided to BPA by another TOP. Generally, BPA studies outages 10 to 16 days prior to the  
87 outage start date.

88 The duration of an outage is not a criteria by which BPA determines which outages to  
89 incorporate in its daily and monthly TTC calculations. The most conservative hourly TTC  
90 calculated for a given outage or combination of outages becomes the governing TTC for the  
91 daily calculation period. Likewise, the most conservative daily TTC for a given outage or  
92 combination of outages becomes the governing TTC for the monthly calculation period.

---

## 93 VI. Priorities Used to Set TTC

---

94 BPA may update assumptions and calculate new TTCs when changes to System conditions will  
95 significantly impact those limits and may use those updated assumptions to determine new  
96 TTC values. The following hierarchy of priorities categorizes the TTC values based on the  
97 time period being calculated and the reason for the change. This prioritization may then be  
98 used to revise the path TTC for a given time period if BPA determines that more recent  
99 assumptions to calculate TTC values better reflect updated System information:

- 100 • **Real-time limit (highest priority):** The “Real-time limit” priority governs when BPA  
101 updates the assumptions of System conditions to calculate TTCs during the Real-time  
102 horizon. A change to the TTC calculation with the Real-time priority governs all other  
103 priorities. For example, if BPA receives an update that a scheduled outage will be  
104 extended by two hours early in the Real-time day, BPA may update the assumptions  
105 for the TTC calculation accordingly for the additional two hours and may use those  
106 same updated assumptions to update the TTC. If there are multiple real-time updates  
107 to assumptions for TTC calculations, the most recent TTC calculated governs.
- 108 • **Scheduling limit:** The “scheduling limit” priority may be used occasionally when the  
109 assumptions for the TTC are not governing or an actual scheduling limit has been  
110 imposed. If there is more than one scheduling limit, the lowest scheduling limit  
111 governs until a Real-time limit TTC is submitted.
- 112 • **Pre-schedule forecast:** The “pre-schedule forecast” TTC priority may be used for a  
113 path if the assumptions for the TTC calculations are updated for the pre-schedule  
114 period. For example, for TTCs calculated for flow-based paths that are derived using  
115 nomograms, if the assumptions are re-evaluated just prior to the pre-schedule day to  
116 incorporate updated data inputs, the TTC may be updated. The pre-schedule forecast  
117 TTC governs over the ‘studied’ priority.
- 118 • **Studied:** The “studied” priority is used when there are outages where a study report  
119 has been issued, including those provided by other TOPs. For example, if a study  
120 report is issued evaluating assumptions for line outage system conditions, the TTCs in  
121 that report govern over any lower-priority TTCs for the duration of the line outage  
122 conditions.
- 123 • **Estimated known limit:** The “estimated known limit” priority is used to establish  
124 unstudied TTCs or to define seasonal path TTCs that govern over “short-term  
125 seasonal” or “Path Rating” priorities.
- 126 • **Short-term seasonal:** The “short-term seasonal” priority is used for TTCs issued for  
127 seasonal Path Ratings. As these Ratings may be higher at certain times during the  
128 year, the short-term seasonal priority governs over the Path Rating priority. For  
129 example, if the longer-term Path Rating for a path is 7800 MW, but seasonally this  
130 Rating increases to 8000 MW, the short-term seasonal Rating of 8000 MW governs and  
131 is used to set the TTC during the season to which it applies.
- 132 • **Path Rating:** The “Path Rating” priority is used to set base TTCs using either the  
133 Rating of the paths, TTCs studied using normal conditions, TTCs calculated for the  
134 planning horizon, or all of the above. The lowest value resulting from the above  
135 calculations governs for the given time period and is used to set the TTC. For  
136 example, if under normal conditions the TTC for a path is 4410 MW, but the TTC  
137 calculated for the planning horizon is 4100 MW, the lower TTC of 4100 MW governs and  
138 is used to set the TTC for the path.

- **Informational limit (lowest priority):** The “informational limit” is used while establishing the initial setup of paths within the scheduling and reservation system. The informational limit is equal to the initial Path Rating of the path.

## VII. Rated System Path Methodology for BPA’s Paths

This section describes how BPA implements the Rated System Path methodology for its paths.

### BPA’s Paths

The following tables list BPA’s paths. BPA has a combination of 1:1 and flow-based paths, and uses the Rated System Path methodology to calculate ATC for both.

Table 1, BPA’s 1:1 Paths

1:1 Path Name	Direction	1:1 OASIS Path Name
Northern Intertie	N>S	NI_TOTL_N>S
Northern Intertie	S>N	NI_TOTL_S>N
West of Garrison <sup>4</sup>	E>W	WOGARR_E>W
West of Garrison <sup>5</sup>	W>E	WOGARR_W>E
La Grande	W>E	LAGR_W>E
La Grande	E>W	LAGR_E>W
Montana Intertie	E>W	MI_E>W
Reno-Alturas	N>S	RATS_N>S
Reno-Alturas	S>N	RATS_S>N
AC Intertie (NWACI)	N>S	AC_N>S
AC Intertie (NWACI)	S>N	AC_S>N
Pacific DC Intertie (PDCI)	S>N	DC_S>N
Pacific DC Intertie (PDCI)	N>S	DC_N>S
Rock Creek Wind	Gen	ROCKCK_GEN
John Day Wind	Gen	JDWIND_GEN
Satsop Injection	Gen	SATSOP_GEN

<sup>4</sup> and <sup>5</sup> BPA treats West of Garrison with the same rating as the Montana to Northwest Path (Path 8 in the WECC Path Rating Catalog).

Table 2, BPA's Flow-Based Paths

Flow-based Path Name	Direction	Flow-based OASIS Path Name	Transmission Line Components	Case used for base ETC calculation
North of Hanford	N>S	NOHANF	Vantage-Hanford #1 500-kV; Grand Coulee-Hanford #1 500-kV; and Shultz-Wautoma #1 500-kV	Heavy load
North of Hanford	S>N	NOHANF_S>N	Hanford-Vantage #1 500-kV; Hanford-Grand Coulee #1 500-kV; and Wautoma-Shultz #1 500-kV	Heavy load
South of Allston	N>S	SOALSN	<b>BPA-Owned Transmission Lines:</b> Allston-Keeler 500-kV; Lexington-Ross 230-kV; and Allston-St. Helens 115-kV; <b>Portland General Electric-Owned Transmission Lines:</b> Trojan-St. Marys 230-kV; and Trojan-Harborton 230-kV; <b>PacifiCorp-Owned Transmission Lines:</b> Merwin-St. Johns 115-kV; Astoria-Seaside 115-kV; and Clatsop 230/115-kV	Heavy load
Raver-Paul	N>S	RAVR_PAUL	Raver-Paul #1 500-kV <b>When Raver-Paul #1 500-kV is out of service, the following lines are monitored:</b> Raver-Paul #1 500-kV; St. Clair-South Tacoma #1 230-kV; Chehalis-Covington #1 230-kV; Frederickson-St. Clair 115-kV; and Electron Heights-Blumaer 115-kV	Heavy load
Cross Cascades North	E>W	C-CASC_N	<b>BPA-Owned Transmission Lines:</b> Schultz-Raver #1, #3, & #4 500-kV; Schultz-Echo Lake #1 500-kV; Chief Joseph-Monroe #1 500-kV; Chief Joseph-Snohomish #3 & #4 345-kV; Rocky Reach-Maple Valley #1 345-kV; Grand Coulee-Olympia #1 287-kV; and Bettas Road-Covington #1 230-kV; <b>Puget Sound Energy-Owned Transmission Line:</b> Rocky Reach-Cascade 230-kV	Heavy load



Flow-based Path Name	Direction	Flow-based OASIS Path Name	Transmission Line Components	Case used for base ETC calculation
Cross Cascades South	E>W	C-CACS_S	<p><b>BPA-Owned Transmission Lines:</b>            Big-Eddy-Ostrander #1 500-kV;            Ashe-Marion #2 500-kV;            Buckley-Marion #1 500-kV;            Knight-Ostrander #1 500-kV;            John Day-Marion #1 500-kV;            McNary-Ross #1 345-kV;            Big Eddy-Chemawa #1 230-kV;            Big Eddy-McLoughlin #1 &amp; #2 230-kV;            Midway-North Bonneville #1 230-kV;            Jones Canyon-Santiam #1 230-kV; and            Big Eddy-Troutdale #1 230-kV</p> <p><b>PGE-Owned Transmission Line:</b>            Round Butte-Bethel 230-kV</p>	Heavy load
West of McNary	E>W	WOMCNY	Coyote Springs-Slatt #1 500-kV; McNary-Ross #1 345-kV; Harvalum-Big Eddy #1 230-kV; Jones Canyon-Santiam #1 230-kV; and McNary-John Day #2 500-kV	Heavy load
West of Slatt	E>W	WOSLATT	Slatt-Buckley #1 500-kV; and Slatt-John Day #1 500-kV	Heavy load
West of John Day	E>W	WOJD_E>W	John Day-Big Eddy #1 500-kV; John Day-Big Eddy #2 500-kV; and John Day-Marion #1 500-kV	Heavy load
South of Boundary	N>S	SBNDRY_N>S	Boundary-Bell #1 230-kV; Boundary-Bell #3 230-kV; Boundary-Usk #1 230-kV; and Boundary 230/115-kV Transformer #1	Heavy load
Columbia Injection	N>S	CLMBIA_N>S	<p><b>BPA-Owned Transmission Lines:</b>            Columbia-Grand Coulee #1 230-kV;            Columbia-Grand Coulee #3 230-kV;            Columbia-Rocky Reach #1 230-kV;            Columbia-Valhalla #1 115-kV; and            Columbia-Valhalla #2 115-kV;</p> <p><b>Chelan PUD-Owned Transmission Line:</b>            Columbia-Rocky Reach #2 230-kV</p> <p><b>Douglas PUD-Owned Transmission Line:</b>            Rapids-Columbia #1 230k</p>	Heavy load

Flow-based Path Name	Direction	Flow-based OASIS Path Name	Transmission Line Components	Case used for base ETC calculation
Wanapum Injection	N>S	WANAPM_N>S	<b>BPA-Owned Transmission Line:</b> Vantage-Midway #1 230-kV; <b>Grant PUD-Owned Transmission Line:</b> Priest Rapids-Midway #3 230-kV	Heavy load
West of Lower Monumental (West of LoMo)	E>W	W_LOMO_E>W	Lower Monumental-Ashe 500-kV; Lower Monumental-Hanford 500-kV; and Lower Monumental-McNary 500-kV	Heavy load
North of Echo Lake	S>N	N_ECOL_S>N	Echo Lake-Monroe-SnoKing Tap #1 500-kV; Echo Lake-Maple Valley #1 500-kV; Echo Lake-Maple Valley #2 500-kV; and Covington-Maple Valley #2 230-kV	Heavy load
South of Custer	N>S	SCSTER_N>S	Custer-Monroe #1 500-kV; Custer-Monroe #2 500-kV; Custer-Bellingham #1 230-kV; and Custer-Murray #1 230-kV	Heavy load
North of Grizzly	N>S	GRZN_N>S	Buckley-Grizzly #1 500-kV; John Day-Grizzly #1 500-kV; John Day-Grizzly #2 500-kV; and Maupin-Redmond #1 230-kV	Heavy load
North of Pearl	S>N	NOPE_S>N	<b>BPA-Owned Transmission Line:</b> Pearl-Keeler #1 500-kV; <b>BPA/Portland General Electric Jointly Owned Lines:</b> Pearl-Sherwood #1 & #2 230-kV; Pearl Tap to the Mcloughlin-Sherwood #1 230-kV	Heavy load
West of Hatwai	E>W	WOH_E>W	Hatwai-Lower Granite #1 500-kV; Bell-Grand Coulee #6 500-kV; Bell-Grand Coulee #3 230-kV; Bell-Grand Coulee #5 230-kV; Westside-Grand Coulee #1 230-kV; Dry Creek-Talbot 230-kV; North Lewiston-Tucannon River #1 115-kV; Devils Gap-Stratford 115-kV; Lind-Warden 115-kV; Creston-Bell #1 115-kV; and Dry Gulch-Pomeroy 69-kV	Light load

## 149 **Calculating TTC**

### 150 **Data and Assumptions**

151 When calculating TTC for its paths, BPA uses WECC base cases that utilize data and  
152 assumptions consistent with the time period being studied.

153 BPA uses the following data and assumptions in the WECC base cases when calculating  
154 TTCs for its paths:

155 BPA models all existing System Elements, including but not limited to any transmission  
156 additions and retirements, in their normal operating condition for the assumed initial  
157 conditions, up to the time horizon in which BPA begins modeling planned outages.

158 The WECC base cases include generators and phase shifters that meet the guidelines  
159 set out in the WECC Data Preparation Manual.

160 BPA uses the seasonal Load forecasts contained in the WECC base cases for each BAA.

161 Generation and Transmission Facility additions and retirements within the WECC  
162 footprint are included in the WECC seasonal operating base cases for the season in  
163 which they are energized/de-energized, respectively. BPA engineers modify the WECC  
164 base cases to reflect the actual dates of energization/de-energization, as well as  
165 expected generation for the timeframe under study.

166 The WECC base cases include Facility Ratings as provided to WECC by the Transmission  
167 Owners and Generator Owners.

168 If Facility changes are made by BPA or another entity, then the base cases will be  
169 updated to reflect these changes with a mid-season update.

170 The approved seasonal operating base cases that include the Facility changes will not  
171 be used until 0 to 16 days prior to the energization or implementation of the Facility  
172 change.

173 For periods beyond two weeks, the WECC base cases will be updated as necessary to  
174 perform seasonal studies for the current or upcoming season in accordance with the  
175 current BPA study processes.

176 For all paths, except West of Garrison and Northern Intertie South to North, BPA uses  
177 the all lines in service TTC from the relevant seasonal studies when there are no  
178 studied outages to set the TTC of the path for the corresponding seasonal time  
179 periods.

180 For West of Garrison, for the seasons or time periods in which the seasonal studies  
181 have not been completed, the most recent year's seasonal study results will be used  
182 for setting the TTC for the path.

183 For Northern Intertie South to North, for the seasons or time periods in which the  
184 seasonal studies have not been completed, the most recent year’s seasonal study  
185 results will be used for setting the TTC. BPA uses the minimum TTC from the relevant  
186 seasonal studies to set the TTC of the path for periods from the next day and  
187 beyond. For the Real-time horizon, when there are no studied outages, BPA uses the  
188 maximum TTC from the relevant seasonal studies to set the TTC of the path.

189 BPA models Special Protection Systems (BPA uses the term Remedial Action Schemes  
190 or RAS) that currently exist or are projected for implementation within the studied  
191 time horizon.

192 The WECC base cases include all series compensation for each line at the expected  
193 operating level.

194 BPA uses no other modeling requirements for calculating TTC in addition to those  
195 specified in this document.

### 196 **Process to Determine TTC**

197 BPA adjusts generation and Load levels, and planned outages, within the WECC power-  
198 flow base cases to determine the TTC that can be simulated for each of its paths, while at  
199 the same time satisfying all operations planning criteria contingencies, as follows:

200 BPA studies single and multiple contingencies that are relevant to the path being studied.

201 When modeling normal conditions, BPA models all Transmission Elements in BPA’s BAA and  
202 adjacent BAAs at or below 100 percent of their continuous Rating. Any reliability  
203 constraints requested by another Transmission Operator will also be included.

204 BPA models contingencies as per the current version of “RC West System Operating Limits  
205 Methodology for the Operations Horizon” (RC West SOL Methodology) posted on RC West’s  
206 website.

207 When modeling contingencies, BPA determines TTCs by stressing the system until flows  
208 exceed emergency Facility Ratings or voltages fall outside emergency system voltage  
209 limits (i.e., the post-Contingency state). BPA does this by simulating transfers performed  
210 through the adjustment of generation and load. If a facility does not have an emergency  
211 Facility Rating, the normal Facility Rating is used. If there is no emergency system voltage  
212 limit, the normal system voltage limit is used. By meeting the criteria in the RC West SOL  
213 Methodology, uncontrolled separation should not occur. BPA does not take into account  
214 expected transmission uses in the determination of TTC.

215 BPA’s paths listed below are bi-directional and have TTCs in both the prevailing and non-  
216 prevailing direction of flow.

- 217 • Northern Intertie
- 218 • West of Garrison
- 219 • La Grande
- 220 • Reno-Alturas
- 221 • AC Intertie (NWACI)
- 222 • Pacific DC Intertie (PDCI)

223           • North of Hanford

224           All of BPA’s other paths are one directional, in the prevailing direction of flow, and have  
225           studied TTCs that are established for the prevailing direction of flow.

226           For paths where TTC varies due to simultaneous interaction with one or more other paths,  
227           BPA develops a nomogram, represented either by an equation or its graphical  
228           representation, describing the interaction of the paths and the resulting TTC under  
229           specified conditions. BPA then calculates a value, based on that nomogram and  
230           forecasted System conditions for the time period studied, to develop its TTC values for  
231           the affected paths.

232           BPA or the adjacent path TOP identifies when the new or increased TTC for a path being  
233           studied by BPA or the adjacent path TOP has an adverse impact on the TTC value of  
234           another existing path by modeling the flow on the path being studied at its proposed new  
235           TTC level, while simultaneously modeling the flow on the existing path at its TTC level. In  
236           doing so, BPA or the adjacent path TOP honors the reliability criteria described above.  
237           BPA or the adjacent path TOP includes the resolution of this adverse impact in its study  
238           report for the path.

239           BPA has Transmission Ownership Agreements where multiple ownerships of Transmission  
240           rights exist on a path. TTC for the affected paths is allocated according to contractual  
241           ownership rights.

242           The ratings for BPA’s paths whose ratings were established, known, and used in operation  
243           since January 1, 1994, have been re-established using updated methods. BPA studies its  
244           paths, with the exception of La Grande, on a periodic basis and reconfirms the rating of  
245           each path based on these studies. These ratings are then used to establish the TTC for  
246           the path.

247           For the La Grande path, BPA uses the Accepted Rating of the path as defined in the WECC  
248           Path Rating Catalog. BPA’s La Grande path is part of the NW-Idaho path (WECC Path  
249           14). The rating of Path 14 was reconfirmed through an updated study in 2010 when the  
250           path definition had to be modified due to the addition of the Hemingway Substation by  
251           PacifiCorp and Idaho Power.

252           BPA establishes the TTC at the lesser of the maximum allowable contractual allocation, or  
253           the reliability limit determined by the Transmission Operator. The reliability limit  
254           includes, but is not limited to, any System Operating Limit for an ATC path.

255           BPA creates a study report that describes the TTC applicable to the outages during the  
256           studied time period and includes the limiting Contingencies and the limiting cause for the  
257           calculated TTC. The RC West SOL Methodology document defines the steps taken and  
258           assumptions BPA used to determine TTC for each path. BPA creates a study report for  
259           each study it performs. The study report relies on the basic assumptions included in RC  
260           West SOL methodology and identifies any changes to those basic assumptions.

261           Information regarding TTCs is shared electronically between the appropriate BPA  
262           organizations within seven calendar days of the finalization of the study report for the TTCs.  
263           BPA sends a notice to all TSPs for the paths listed in Table 1 where there are multiple TSPs  
264           prior to limitations in TTCs.

265 A path for which BPA does not perform studies to determine the most current value of TTC is  
266 Reno - Alturas. For Reno-Alturas, NV Energy determines TTC. The TTC is provided to BPA and  
267 BPA then sends a Notice of Planned Path Limitation.

## 268 **Calculating Firm Transmission Service for Paths**

### 269 **Calculating Firm Existing Transmission Commitments (ETC<sub>F</sub>)**

270 When calculating ETC<sub>F</sub> for all time periods for its paths, BPA uses the following algorithm:

$$271 \text{ETC}_F = \text{NL}_F + \text{NITS}_F + \text{GF}_F + \text{PTP}_F + \text{ROR}_F + \text{OS}_F$$

272 **Where:**

273 ETC<sub>F</sub> is the firm ETC for the ATC path.

274 **NL<sub>F</sub>** is the firm capacity set aside to serve peak Native Load forecast commitments, to include  
275 losses, and Native Load growth, not otherwise included in Transmission Reliability Margin or  
276 Capacity Benefit Margin.

277 BPA does not have any NL<sub>F</sub>, and thus sets NL<sub>F</sub> at zero for all of its paths for all time  
278 periods. All of BPA's firm Transmission obligations are captured in the NITS<sub>F</sub>, PTP<sub>F</sub>, GF<sub>F</sub>  
279 and ROR<sub>F</sub> components of the ETC<sub>F</sub> algorithm.

280 **NITS<sub>F</sub>** is the firm capacity reserved for Network Integration Transmission Service serving Load,  
281 to include losses, and Load growth, not otherwise included in Transmission Reliability Margin  
282 or Capacity Benefit Margin.

283 For BPA's 1:1 paths, BPA uses ten year maximum 1 in 10 coincidental peak load forecasts  
284 to encumber capacity for customers with a designated resource of FCRPS. For customers  
285 with a designated resource outside of FCRPS, BPA uses the capacity designated for the  
286 resource to encumber capacity across these paths.

287 On the La Grande W>E ATC path, BPA uses a different methodology to encumber capacity  
288 for customers with a designated resource of FCRPS. BPA encumbers firm capacity based  
289 on the coincidental 1 in 10 peak forecast, less critical water forecasts of the federal  
290 generation located in the Idaho BAA. Idaho Power then specifies what will be served  
291 across La Grande W>E and BPA encumbers this amount for this path.

292 For BPA's flow-based paths, BPA accounts for NITS<sub>F</sub> obligations with a combination of base  
293 ETC and interim ETC calculations, as described further in this document.

294 **GF<sub>F</sub>** is the firm capacity set aside for grandfathered contracts for energy and/or Transmission  
295 Service, where executed prior to the effective date of a Transmission Service Provider's Open  
296 Access Transmission Tariff or "safe harbor tariff."

297 The amount of GF<sub>F</sub> BPA encumbers across its 1:1 paths is based on the terms of each  
298 individual contract.

299 For BPA's flow-based paths, BPA accounts for GF<sub>F</sub> obligations with base ETC calculations,  
300 as described further in this document.

301 **PTP<sub>F</sub>** is the firm capacity reserved for confirmed Point-to-Point Transmission Service.

302 In BPA's calculations for 1:1 paths, PTP<sub>F</sub> is equal to the sum of the MW Demands of PTP<sub>F</sub>  
303 reservations or schedules.

304 For BPA's flow-based paths, BPA accounts for PTP<sub>F</sub> obligations with a combination of base  
305 ETC and interim ETC calculations, as described further in this document.

306 For Redirects from conditional short-term firm parent reservations, BPA's ETC accounts  
307 for the parent reservation until the Redirect is confirmed on OASIS. Once the Redirect is  
308 confirmed, BPA's ETC only accounts for the Redirect.

309 For Redirects from long-term firm parent reservations or unconditional short-term firm  
310 parent reservations, BPA's ETC accounts for both the parent reservation and the Redirect  
311 reservation until the Redirect itself is unconditional. Once the Redirect is unconditional,  
312 BPA's ETC only accounts for the Redirect.

313 In some cases, BPA has PTP<sub>F</sub> contracts that give customers the right to schedule between  
314 multiple Points of Receipt (PORs) and Points of Delivery (PODs). However, the customer  
315 can only schedule up to the MW amount specified in their contract. Multiple reservations  
316 are created for these special cases to allow BPA to model each POR-to-POD combination.  
317 The amount encumbered for these cases does not exceed the total PTP<sub>F</sub> rights specified in  
318 the contracts.

319 **ROR<sub>F</sub>** is the firm capacity reserved for roll-over rights for contracts granting Transmission  
320 Customers the right of first refusal to take or continue to take Transmission Service when the  
321 Transmission Customer's Transmission Service contract expires or is eligible for renewal.

322 BPA assumes that all of its Transmission Service Agreements eligible to roll-over in the  
323 future will be rolled over. If a Transmission Customer chooses not to exercise its roll-over  
324 rights by the required deadline, BPA no longer encumbers capacity for roll-over rights for  
325 that Transmission Customer.

326 **OS<sub>F</sub>** is the firm capacity reserved for any other service(s), contract(s), or agreement(s) not  
327 specified above using Firm Transmission Service as specified in the ATCID.

328 BPA has no OS<sub>F</sub> and thus sets OS<sub>F</sub> at zero for all of its paths for all time periods. All of  
329 BPA's firm Transmission obligations are captured in the NITS<sub>F</sub>, PTP<sub>F</sub>, GF<sub>F</sub> and ROR<sub>F</sub>  
330 components of the ETC<sub>F</sub> algorithm.

331 Although BPA uses the above algorithm to calculate ETC<sub>F</sub> for all of its paths, BPA's ETC<sub>F</sub>  
332 calculation methodology differs between its 1:1 and flow-based paths. For 1:1 paths, BPA  
333 calculates ETC<sub>F</sub> by assuming that 1 MW of reserved firm capacity equals 1 MW of ETC<sub>F</sub> across  
334 that path. The POR/POD combinations for 1:1 ATC paths that impact ETC<sub>F</sub> can be found under  
335 the Transmission Availability section of BPA's website. For the flow-based paths, BPA  
336 calculates ETC<sub>F</sub> by summing the base ETC from power-flow ETC studies with interim ETC<sub>F</sub>  
337 calculated using PTFDs.

338 **Determining base ETC for Flow-Based Paths**

339 **Use of WECC Base Cases to Determine Base ETC**

340 BPA uses the WECC seasonal base cases and modifies them to calculate the base ETC  
341 for its flow-based paths. BPA refers to these base cases as ETC Cases.

342 **Determining Base ETC for Heavy Load Base Cases**

343 BPA creates monthly heavy load ETC Cases to calculate base ETC values. BPA's ETC  
344 cases are produced using a power flow model that computes how much power will  
345 flow over each flow-based path for the assumed Load and generation levels for each  
346 time period studied. Counterflows are inherently modeled in these base cases.

347 BPA uses the following assumptions to create heavy load ETC Cases for its base ETC  
348 calculations:

349 **System topology:** Normal operating conditions are used. BPA uses the WECC Winter  
350 seasonal case for its November through March ETC base cases, the WECC Spring  
351 seasonal case for its April and May ETC base cases, and the WECC Summer seasonal  
352 case for its June through October ETC base cases.

353 **Load:** BPA uses loads contained in the WECC seasonal base cases for the time periods  
354 being studied, along with any updates to those loads BPA may have made after the  
355 WECC base cases were received from WECC.

- 356 • **NITS<sub>F</sub>, PTP<sub>F</sub> and GF<sub>F</sub>:** BPA assumes a 1-in-2 year monthly peak load forecast in all  
357 its monthly ETC cases

358 **Generation:** For the generators in BPA's BAA or directly interconnected to BPA, BPA  
359 uses the following generation assumptions:

360 **FCRPS:** For the FCRPS resources serving NITS<sub>F</sub>, PTP<sub>F</sub>, and GF<sub>F</sub> Long-Term Reservations,  
361 generation levels are set using a multiple-step process. For all time periods studied,  
362 BPA uses the following process:

- 363 • The Columbia Generating Station is assumed to be on-line at full load in the ETC  
364 cases. Generation levels at the Libby, Hungry Horse, Dworshak, and Albeni Falls  
365 projects are based on the 90th percentile rate case generation values for these  
366 projects. The generation levels at the Willamette Valley projects<sup>6</sup> are set at a  
367 monthly fleet-aggregate lower 10th percentile of Heavy Load Hour block  
368 generation from the planning period of record and adjusted as needed to

---

<sup>6</sup> Willamette Valley projects include: Big Cliff, Cougar, Detroit, Dexter, Foster, Green Peter, Hills Creek, Lookout Point, and Lost Creek.



369 accurately reflect operations that BPA knows are in place. **Nameplate Adjusted**  
370 **Method:** When creating heavy load ETC Cases, generation levels for all other  
371 federal hydro projects<sup>7</sup> are set by first determining the nameplate for each project  
372 and then adjusting such nameplates by outages forecasted for the particular  
373 plants. Next in the month of August, the Lower Snake plants (Lower Granite,  
374 Lower Monumental, Little Goose, and Ice Harbor) are capped at the observed  
375 project outflow over the past ten Augusts. Then multiple generation scenarios are  
376 modelled by stressing one of three different “zones” of Federal hydro resources to  
377 the nameplate adjusted generation levels described above and scaling the  
378 generation at the remaining Federal hydro projects to match the sum of the  
379 demands for all contracts that call out non-specific Federal hydroelectric projects  
380 as PORs after adjusting these demands for the portion served by Columbia  
381 Generating Station, Libby, Hungry Horse, Dworshak, Albeni Falls, and the  
382 Willamette Valley projects. The Federal PTP demands at each project are then  
383 added to this result to obtain the final assumed generation level for each Federal  
384 hydro project.

385 **Non-Federal Thermal Generators:** Non-federal thermal generators associated with  
386 PTP<sub>F</sub>, GF<sub>F</sub> and NITS<sub>F</sub> Transmission Service for BPA’s area and all adjacent TSP areas are  
387 set at up to the contract Demand.

388 **Wind Generators:**

- 389 • **PTP<sub>F</sub>:** Wind generators associated with PTP<sub>F</sub> Long-Term Reservations are set at  
390 the following depending on the scenarios being run:
    - 391 ○ Modeled on at 100 percent of the contract demand for the wind  
392 generator; or
    - 393 ○ Modeled off
  - 394 • **NITS<sub>F</sub>:** The flow-based path impacts of wind generators identified as  
395 designated network resources in NITS<sub>F</sub> contracts or in the NT Resources  
396 Memorandum of Agreement in BPA’s area are determined on a flow-based  
397 path-by-flow-based path basis and set at the greater of the following:
    - 398 ○ The wind generators modeled on at the designated amount of the wind  
399 generators; or,
    - 400 ○ The wind generators modeled off and replaced by increasing the FCRPS  
401 generation level by the designated amount of the wind generators using  
402 the Nameplate Adjusted Method for all ETC cases described above.
- 403 Wind generators designated as network resources in NITS<sub>F</sub> contracts for all  
404 adjacent TSPs are modeled up to the designated amount.

---

<sup>7</sup> Federal hydro projects include: Grand Coulee, Chief Joseph, Lower Granite, Lower Monumental, Little Goose, Ice Harbor, McNary, John Day, The Dalles, Bonneville.

405 • **GF<sub>F</sub>**: BPA and all of BPA’s adjacent TSPs have no GF<sub>F</sub> contracts for wind  
406 generators.

407 **Behind the Meter Generators:** Non-federal resources that do not require  
408 Transmission Service over the FCRTS and that are behind the meter are set up to  
409 levels used in BPA’s process for power system planning studies.

410 **Mid-Columbia Hydro Projects:** Generation levels at the non-federal Mid-Columbia  
411 hydro projects are set up to 90 percent of their historical output by season.

412 When creating heavy load ETC cases, if there is more generation than load plus  
413 committed exports in the base case, BPA reduces excess generation to bring  
414 generation and load into balance in order to solve the power flow model. This  
415 generation reduction is done by reducing all excess generation pro rata, except for the  
416 stressed FCRPS zone.

417 Starting with the November 2023 studies and going forward, BPA reduces all excess  
418 generation by aggregating generators by fuel type, and scaling the aggregated fuel  
419 type groups. Generation is then reduced based on how each generator participates as  
420 part of the scaled generation fleet, with the exception of the stressed FCRPS zone.  
421 Columbia Generation Station is always modeled on, in both methodologies.

422 When creating heavy load ETC cases, if there is more load and committed exports than  
423 generation in the ETC base case, BPA reduces exports on the AC Intertie and Pacific DC  
424 Intertie in the ETC base case. This is done to solve the power flow model.

#### 425 **Sensitivity Studies for Heavy Load Base Cases**

426 In calculating its base ETC values, BPA runs ETC case scenarios for three different  
427 sensitivities: the Canadian Entitlement Return (CER) obligation modeled on or off,  
428 wind resources designated to serve PTP<sub>F</sub> and NITS<sub>F</sub> on or off, and stressing the three  
429 different zones of the FCRPS.

430 For the FCRPS scenarios, the three “zones” that are stressed individually in the  
431 scenarios are made up of the following projects: (i) Upper Columbia zone includes  
432 Grand Coulee and Chief Joseph; (ii) Lower Snake zone includes Lower Monumental,  
433 Lower Granite, Little Goose, and Ice Harbor; and (iii) Lower Columbia zone includes  
434 McNary, John Day, The Dalles and Bonneville.

435 For the CER Scenarios, BPA models the FCRPS generators delivering or not delivering  
436 energy to Canada in the amount specified in the Canadian Entitlement Agreement.

437 In the CER on scenarios, BPA models the exports to Canada at the Canadian  
438 Entitlement Agreement contract level. The FCRPS generation is modeled using the  
439 Nameplate Adjusted Method.

440 In the CER off scenarios, BPA models imports from Canada at the contract rights that  
441 customers have across the Northern Intertie N>S. The FCRPS generation is also  
442 modeled using the Nameplate Adjusted Method.

443 For the wind resource scenarios, see above for a description of the base ETC  
444 assumptions for wind generators serving  $PTP_F$  and  $NITS_F$ .

445 Therefore, in its heavy load base ETC sensitivity analysis, BPA models the following 6  
446 scenarios:

- 447 1. Wind modeled off/Upper Columbia stressed
- 448 2. Wind modeled off/Lower Snake stressed
- 449 3. Wind modeled off/Lower Columbia stressed
- 450 4. Wind modeled on/Upper Columbia stressed
- 451 5. Wind modeled on/Lower Snake stressed
- 452 6. Wind modeled on/Lower Columbia stressed

453 All scenarios are run with CER modeled on and off for all months.

454 BPA uses the highest base ETC value calculated from these scenarios in its firm ATC  
455 calculations across the flow-based paths. BPA uses the lowest base ETC value from  
456 these scenarios in its non-firm ATC calculations across the flow-based paths.

#### 457 **Determining Base ETC and Sensitivities for Light Load Base Cases**

458 BPA uses the WECC Winter seasonal light load case as the starting point for its Winter  
459 seasonal light load ETC base case. The ETC from this case is used as the base ETC for  
460 the months of November through March.

461 BPA uses the WECC Summer seasonal light load case as the starting point for its  
462 Summer light load ETC base case. The ETC from the Summer case is used as the base  
463 ETC for the months of June through October.

464 If a WECC Spring seasonal light load case is available, BPA uses that case as the  
465 starting point for its Spring seasonal light load ETC base case. The ETC from this case  
466 is used as the base ETC for the months of April and May. If the WECC Spring seasonal  
467 light load case is not available, the higher of the base ETCs from either the Winter or  
468 Summer case are used as the base ETC for April and May.

469 BPA uses the following assumptions in light load ETC base cases:

- 470 a. System topology: Normal operating conditions are used.
- 471 b. Loads: Loads from the WECC light load cases are used. For Montana loads only,  
472 BPA compares the loads in the WECC seasonal light load case with the seasonal  
473 light loads supplied by Montana Power, and uses the lowest of the two values in  
474 order to properly stress the light load case.
- 475 c. Generation: BPA uses generation assumptions from historical data. Canadian  
476 Entitlement is modeled as delivering energy to Canada in the amount specified  
477 in the Canadian Entitlement Agreement.

478 There are two sensitivity studies performed for the light load ETC base cases:

- 479 a. Federal generation east of the path is increased, and a corresponding amount  
480 of federal generation west of the path is reduced

481                    b. Federal generation east of the path is reduced, and a corresponding amount of  
482                    federal generation west of the path is increased

483                    BPA uses the highest base ETC value calculated from these scenarios in its firm ATC  
484                    calculations across the flow-based paths where light load cases are utilized. BPA uses  
485                    the lowest base ETC value from these scenarios in its non-firm ATC calculations across  
486                    the flow-based paths where light load cases are utilized.

#### 487                    **Calculating Interim ETC<sub>F</sub> for Flow-based Paths**

488                    To calculate the impacts for all NITS<sub>F</sub> and PTP<sub>F</sub> reservations that were not modeled in the  
489                    base ETC cases, BPA uses PTDF analysis on the demand in each reservation. PTDF analysis  
490                    is the fraction of energy (expressed as a percentage or as a decimal) that will flow across  
491                    BPA’s monitored flow-based paths as that energy is injected at a POR (or source) relative  
492                    to a slack bus, and withdrawn at a POD (or sink) relative to a slack bus, for each flow-  
493                    based path.

494                    PTDF impacts are calculated as per BPA’s Transmission Service Requests Evaluation  
495                    business practice. If a reservation’s impact on a flow-based path is determined to be *de*  
496                    *minimis* per the Transmission Service Requests Evaluation business practice, then BPA  
497                    deems the impact of the reservation to be zero when calculating ETC<sub>F</sub> used in the ATC<sub>F</sub>  
498                    calculation.

499                    The sum of these positive impacts is referred to as the interim ETC<sub>F</sub> value, and is added to  
500                    the base ETC values to produce a final ETC<sub>F</sub> value for each time period for each flow-  
501                    based path.

#### 502                    **Outages in PTDF Calculations**

503                    BPA calculates PTDFs by adjusting the WECC base cases to include transmission  
504                    outages in BPA’s outage system for BPA’s area and any adjacent TSP areas.  
505                    Transmission outages for Transmission Lines, sections of Transmission Lines,  
506                    transformers and taps are used to set branches as *open* in the appropriate base  
507                    case for the hour being calculated.

508                    When the Raver-Paul 500-kV line is out of service, the PTDFs that BPA calculates and  
509                    uses for the Raver-Paul path are based on the monitored lines for this path that are  
510                    outlined in Table 2. This allows BPA to properly manage the Raver-Paul path in this  
511                    outage situation.

#### 512                    **Outage Criteria in ETC Calculations**

513                    BPA uses the outage planning timeline described in the “Outages” section. The  
514                    following criteria determine which outages are incorporated into BPA’s hourly, daily  
515                    and monthly ETC calculations:

#### 516                    **Hourly ETC Calculations**

517                    For its hourly ETC calculations, BPA uses hourly PTDFs published at least once per  
518                    day.

519 **Daily ETC Calculations**

520 For its daily ETC calculations, BPA uses the most recent PTDFs published for the  
521 hour ending 11 of each day, since hour ending 11 tends to have the highest  
522 coincidence of outages. Therefore all Transmission outages scheduled to occur  
523 during the hour ending 11, regardless of the duration of the outage, impact daily  
524 ETC calculations.

525 BPA includes Transmission outages in daily ETC calculations beyond the 10- to 16-  
526 day planned outage study period if the outage is officially scheduled in BPA's  
527 outage system.

528 **Monthly ETC Calculations**

529 For its monthly ETC calculations, BPA uses the most recent daily PTDFs published  
530 for the first Tuesday of that month. BPA includes Transmission outages in monthly  
531 ETC calculations beyond the 10- to 16-day planned outage study period if the  
532 outage is officially scheduled in BPA's outage system.

533 **Source/POR and Sink/POD Identification and Mapping**

534 In the ETC components of its flow-based path ATC calculations, BPA accounts for  
535 source and sink for Transmission Service through the following processes:

536 BPA maps the source/POR and sink/POD to the WECC base cases. In this mapping, BPA  
537 has assigned network bus points that represent the primary interface for  
538 Interconnection with specific generation projects, adjacent electrical Systems or  
539 Load-serving entities and trading hubs. Some adjacent electrical Systems have  
540 multiple Interconnection points deemed as PORs/sources or PODs/sinks. The mapping  
541 of these points is published in the Transmission Service Contract Points list on BPA's  
542 OASIS homepage.

543 BPA calculates weighted PTDFs for Sources/PORs as follows:

- 544 1. The PTDF weighting for the FCRPS/BPA Power PTDF varies by time period and path  
545 based on stress scenarios. The PTDF weighting is derived from generation  
546 forecasts of the federal resources, for calculations for the next hour through  
547 approximately two weeks. Beyond this time frame, BPA derives the weighting of  
548 the PTDF by applying the generation dispatch determined in the ETC Cases.
- 549 2. BPA derives the PTDF weighting for the Mid-Columbia bus point by applying the  
550 generation dispatch determined in the ETC Cases.
- 551 3. BPA has grouped the generators in its adjacent BAAs based on the primary  
552 interface between each BAA and the generation projects within that BAA  
553 (excluding some remote generators that are scheduled via NERC e-Tag). These  
554 groupings are assigned weighted PTDFs that represent how the generators  
555 participate in the group and are used to evaluate transactions within and between  
556 adjacent BAAs that do not include BPAT. BPA derives the PTDF weightings for  
557 these points from BAA-provided generation estimates or by applying the generation  
558 dispatch determined in the ETC Cases if generation estimates are not available. In

559 the ETC Cases, these generators are modeled up to the long-term firm  
560 Transmission rights associated with the generators.

561 BPA calculates weighted PTDFs for Sinks/PODs as follows:

- 562 1. BPA has weighted PTDFs for loads in its adjacent BAAs based on the primary  
563 interface between each BAA and the load within that BAA. The weighting is based  
564 on how the load is distributed in the BAA.
- 565 2. BPA calculates a weighted PTDF to account for unscheduled Network Integration  
566 Transmission Service loads in BPA's BAA that are served from the FCRPS. The  
567 weighting is based on the individual load forecasts for the time period being  
568 calculated.
- 569 3. BPA calculates a weighted load for all of the BPA Power Services customers that  
570 are served via Network Integration Transmission Service agreements. The  
571 weighting is based on the individual load forecasts for the time period being  
572 calculated.
- 573 4. BPA calculates a weighted load for PNGC Power, which is a Joint Operating Entity  
574 made up of several cooperative utilities. The weighting is based on the individual  
575 load forecasts for the time period being calculated.

576 BPA calculates one weighted PTDF that applies to the following Source/POR and  
577 Sink/POD:

- 578 1. BPA calculates a weighed PTDF for the Western Energy Imbalance Market. This  
579 weighting is based on the percentage of Automatic Generation Control response  
580 (which could be zero) carried by each plant in the FCRPS.

## 581 **Calculating Firm Available Transfer Capability (ATC<sub>F</sub>)**

582 When calculating ATC<sub>F</sub> for its paths for all time periods, BPA uses the following algorithm:

$$583 \quad \text{ATC}_F = \text{TTC} - \text{ETC}_F - \text{CBM} - \text{TRM} + \text{Postbacks}_F + \text{Counterflows}_F$$

584 **Where:**

585 ATC<sub>F</sub> is the firm Available Transfer Capability for the ATC path for that period for which ATC<sub>F</sub>  
586 is being calculated.

587 TTC is the Total Transfer Capability of the ATC path for that period.

588 ETC<sub>F</sub> is the sum of existing firm commitments for the ATC path as specified in WEQ-023 during  
589 that period for which ATC<sub>F</sub> is being calculated.

590 For ATC<sub>F</sub> calculations for all time periods, BPA divides ETC<sub>F</sub> into the following variables  
591 within its ATC software:

$$592 \quad \text{ETC}_F = \text{LRES} + \text{SRES} + \text{LETC} - \text{SADJ/ETC Adjustments}$$

593 **Where:**  
594 **LRES** is the sum of positive impacts of BPA’s Long-Term Reservations.  
595 **SRES** is the sum of positive impacts of BPA’s Short-Term Reservations.

596 **LETC** is used to ensure that the amount of  $NITS_F$ ,  $GF_F$ ,  $PTP_F$  and  $ROR_F$  capacity BPA sets  
597 aside in the LRES variable for contracts where BPA gives customers the right to schedule  
598 the capacity reserved between multiple PORs and PODs does not exceed the total capacity  
599 specified in those contracts.

600 LETC is also used to align the ETC calculated in the power flow base case with additional  
601 PTDF calculations in order to balance to the standard OATI calculation. This adjustment is  
602 derived by comparing two values: a) the impacts of the confirmed  $PTP_F$ ,  $GF_F$ ,  $NITS_F$  and  
603  $ROR_F$  Long-Term Reservations derived from the base ETC Cases and b) the impacts of the  
604 same reservations calculated using PTDF Analysis for each flow-based path. The  
605 adjustment for each flow-based path is equal to the difference of these two values.

606 BPA has begun to transition the modeling of Conditional Firm reservations into the ETC  
607 cases. This transition started with the Summer 2024 studies and will be completed with  
608 the Spring 2025 cases. The impacts of Conditional Firm reservations are beings managed  
609 either through LETC or SADJ/ETC Adjustments during the transition period.

610 **SADJ/ETC Adjustments** is the variable BPA uses to make adjustments to  $ETC_F$  not  
611 captured in LRES or SRES.

612 BPA applies one such adjustment to allow for deferral competitions, as required in Section  
613 17.7 of BPA’s OATT. When a deferral reservation is confirmed, BPA applies an SADJ/ETC  
614 Adjustment to hold out capacity for the time period deferred, starting at the latter of five  
615 months out or the service commencement date of the original reservation, to allow for a  
616 competition. At four months out, if no competition is identified, the SADJ/ETC  
617 Adjustment is modified to release the capacity for the fourth month out.

618 BPA uses a SADJ/ETC Adjustment to account for a portion of the firm TRM that BPA  
619 applies on the NI S>N.

620 BPA also uses SADJ/ETC Adjustments to ensure accurate accounting of  $ETC_F$ . These  
621 adjustments may be performed to account for situations such as data modeling  
622 corrections, and are noted in the descriptions of the adjustments.

623 The following diagram illustrates how the variables in BPA’s ATC software correspond to  
 624 the variables in the ETC<sub>F</sub> algorithm.

ETC <sub>F</sub> =	NITS <sub>F</sub>	+	GF <sub>F</sub>	+	PTP <sub>F</sub>	+	ROR <sub>F</sub>
	↓		↓		↓		↓
	LRES		LRES		LRES		LRES
	+				+		
	SRES				SRES		
	+		+		+		+
	LETC		LETC		LETC		LETC
	-		-		-		-
	SADJ/ETC Adjustments		SADJ/ETC Adjustments		SADJ/ETC Adjustments		SADJ/ETC Adjustments

625 **CBM** is the Capacity Benefit Margin for the ATC path during that period.

626 BPA does not maintain CBM and thus sets CBM at zero for all of its paths for all time  
 627 periods.

628 **TRM** is the Transmission Reliability Margin for the ATC path during that period.

629 The description of how BPA implements TRM can be found in BPA’s TRMID, which is posted  
 630 on BPA’s website.

631 **Postbacks<sub>F</sub>** are changes to firm Available Transfer Capability due to a change in the use of  
 632 Transmission Service, as defined in WEQ-023.

633 BPA automatically recalculates ETC<sub>F</sub> to account for changes to Transmission Service  
 634 Requests (such as request types of Recall and Redirect and annulments). Since these  
 635 types of changes to Transmission Service Requests are captured in ETC<sub>F</sub>, BPA treats  
 636 Postbacks<sub>F</sub> as zero for all time periods when calculating ATC<sub>F</sub>.

637 **Counterflows<sub>F</sub>** are adjustments to firm Available Transfer Capability as determined by the  
 638 Transmission Service Provider and specified in their ATCID.

639 BPA does not include confirmed Transmission reservations, expected interchange or  
 640 internal flow counter to the direction of the path being calculated in its ATC<sub>F</sub> calculations.  
 641 BPA’s rationale is that it does not want to offer firm ATC due to counterflow that may not  
 642 be scheduled as this could lead to curtailments of Firm Transmission Service in the Real-  
 643 time horizon. Therefore BPA sets Counterflows<sub>F</sub> at zero for all of its paths for all time  
 644 periods.

645 For flow-based paths, counterflows are automatically modeled in the base ETC cases. In  
 646 instances where the power flow study results in a negative base ETC value, BPA uses zero  
 647 as the base ETC for purposes of calculating ATC<sub>F</sub>. This is done to ensure that BPA does not  
 648 make capacity available as a result of counterflows that may or may not materialize in  
 649 real-time.



## 650 **Calculating Non-Firm Transmission Service for BPA's Paths**

651 BPA calculates  $ETC_{NF}$  and  $ATC_{NF}$  for each of its six non-firm Transmission products. The six  
652 non-firm products are: Secondary Network ( $NITS_{NF6}$ ), Monthly Non-Firm PTP ( $PTP_{NF5}$ ), Weekly  
653 Non-Firm PTP ( $PTP_{NF4}$ ), Daily Non-Firm PTP ( $PTP_{NF3}$ ), Hourly Non-Firm PTP ( $PTP_{NF2}$ ) and  
654 Secondary Non-Firm Hourly PTP ( $PTP_{NF1}$ ).

## 655 **Calculating Non-Firm Existing Transmission Commitments ( $ETC_{NF}$ )**

656 BPA calculates  $ETC_{NF}$  for all time periods and paths using the following algorithm:

$$657 \quad ETC_{NF} = NITS_{NF} + GF_{NF} + PTP_{NF} + OS_{NF}$$

658  $ETC_{NF}$  is calculated for each of BPA's six non-firm Transmission products as follows:

- 659 1.  $ETC_{NF6}$ : includes the  $NITS_{NF6}$  transmission product
- 660 2.  $ETC_{NF5}$ : includes the  $NITS_{NF6}$  and  $PTP_{NF5}$  transmission products
- 661 3.  $ETC_{NF4}$ : includes the  $NITS_{NF6}$ ,  $PTP_{NF5}$  and  $PTP_{NF4}$  transmission products
- 662 4.  $ETC_{NF3}$ : includes the  $NITS_{NF6}$ ,  $PTP_{NF5}$ ,  $PTP_{NF4}$ , and  $PTP_{NF3}$  transmission products
- 663 5.  $ETC_{NF2}$ : includes the  $NITS_{NF6}$ ,  $PTP_{NF5}$ ,  $PTP_{NF4}$ ,  $PTP_{NF3}$  and  $PTP_{NF2}$  transmission products
- 664 6.  $ETC_{NF1}$ : includes the  $NITS_{NF6}$ ,  $PTP_{NF5}$ ,  $PTP_{NF4}$ ,  $PTP_{NF3}$ ,  $PTP_{NF2}$  and  $PTP_{NF1}$  transmission products

### 665 **Where:**

666  $ETC_{NF}$  is the non-firm ETC for the ATC path.

667  $NITS_{NF}$  is the non-firm capacity reserved for Secondary Network Transmission Service, to  
668 include losses, and Load growth not otherwise included in Transmission Reliability Margin or  
669 Capacity Benefit Margin.

670 In BPA's calculations, this is comprised of the  $NITS_{NF6}$  Transmission product. BPA's  $NITS_{NF6}$   
671 calculation does not include losses or Load growth, since losses and Load growth are  
672 already encumbered as firm capacity in  $NITS_F$ .

673  $GF_{NF}$  is the non-firm capacity set aside for grandfathered contracts for energy and/or  
674 Transmission Service, where executed prior to the effective date of a Transmission Service  
675 Provider's Open Access Transmission Tariff or "safe harbor tariff."

676 BPA does not have any grandfathered non-firm Transmission Service obligations and thus  
677 sets  $GF_{NF}$  at zero for all of its paths for all time periods.

678  $PTP_{NF}$  is non-firm capacity reserved for confirmed Point-to-Point Transmission Service.

679 Depending on the  $ETC_{NF}$  being calculated,  $PTP_{NF}$  will include the  $PTP_{NF5}$ ,  $PTP_{NF4}$ ,  $PTP_{NF3}$ ,  
680  $PTP_{NF2}$  and  $PTP_{NF1}$  Transmission products.

681  $OS_{NF}$  is the non-firm capacity reserved for any other service(s), contract(s), or agreement(s)  
682 not specified above using non-firm transmission service as specified in the ATCID.

683 BPA has no  $OS_{NF}$  and thus sets  $OS_{NF}$  at zero for all of its paths for all time periods.

684  $ETC_{NF}$  for 1:1 paths is calculated by assuming that 1 MW of reserved and/or scheduled capacity  
685 results in 1 MW of impact across the 1:1 path. The POR/POD combinations for 1:1 ATC paths  
686 that impact  $ETC_{NF}$  can be found under the Transmission Availability section of BPA's website.

687 When calculating  $ETC_{NF}$  for flow-based paths, BPA sums the positive impacts of reservations  
688 and/or schedules as determined by PTDF analysis, per BPA's Transmission Service Requests  
689 Evaluation business practice. The treatment of *de minimis* impacts in  $ETC_{NF}$  is covered within  
690 the Calculating Non-Firm Available Transfer Capability section below.

### 691 **Calculating Non-Firm Available Transfer Capability ( $ATC_{NF}$ )**

692 BPA calculates  $ATC_{NF}$  for its paths for two horizons: Real-time and Beyond Real-time. The  
693 Real-time horizon begins at 10 p.m. each day for the 24 hours in the next day. The Beyond  
694 Real-time horizon includes hourly for the hours after those included in the Real-time period  
695 as well as daily and monthly calculations.

696 BPA calculates  $ATC_{NF}$  for all time periods and paths using the following algorithm:

$$697 \quad ATC_{NF} = TTC - ETC_F - ETC_{NF} - CBM_S - TRM_U + Postbacks_{NF} + Counterflows_{NF}$$

698  $ATC_{NF}$  is calculated for each of BPA's six non-firm Transmission products as follows:

$$699 \quad 1. \quad ATC_{NF6} = TTC - ETC_F - ETC_{NF6} - CBM_S - TRM_U + Postbacks_{NF} + Counterflows_{NF}$$

$$700 \quad 2. \quad ATC_{NF5} = TTC - ETC_F - ETC_{NF5} - CBM_S - TRM_U + Postbacks_{NF} + Counterflows_{NF}$$

$$701 \quad 3. \quad ATC_{NF4} = TTC - ETC_F - ETC_{NF4} - CBM_S - TRM_U + Postbacks_{NF} + Counterflows_{NF}$$

$$702 \quad 4. \quad ATC_{NF3} = TTC - ETC_F - ETC_{NF3} - CBM_S - TRM_U + Postbacks_{NF} + Counterflows_{NF}$$

$$703 \quad 5. \quad ATC_{NF2} = TTC - ETC_F - ETC_{NF2} - CBM_S - TRM_U + Postbacks_{NF} + Counterflows_{NF}$$

$$704 \quad 6. \quad ATC_{NF1} = TTC - ETC_F - ETC_{NF1} - CBM_S - TRM_U + Postbacks_{NF} + Counterflows_{NF}$$

705 Table 3 outlines the differences in how the  $ATC_{NF}$  algorithm components are calculated  
706 between the Beyond Real-time and Real-time time horizons.

707

**Table 3, ATC<sub>NF</sub> Calculation for Beyond Real-Time and Real-Time Horizons**

Algorithm Component	Beyond Real-time	Real-time
TTC	As described in TTC section in the ATCID	Same
ETC <sub>F</sub>	Calculated using reservations and base ETC cases for flow-based paths <ul style="list-style-type: none"> <li>• <i>De minimis</i> impacts are treated as zero in ETC<sub>F</sub></li> </ul>	Calculated using schedules <ul style="list-style-type: none"> <li>• <i>De minimis</i> impacts are included in ETC<sub>F</sub></li> </ul>
ETC <sub>NF</sub>	Calculated using reservations <ul style="list-style-type: none"> <li>• <i>De minimis</i> impacts are treated as zero in ETC<sub>NF</sub></li> </ul>	Calculated using reservations until scheduled, then calculated using schedules <ul style="list-style-type: none"> <li>• <i>De minimis</i> impacts are included in ETC<sub>NF</sub> for both reservations and schedules</li> </ul>
CBM <sub>S</sub>	N/A	N/A
TRM <sub>U</sub>	As described in the TRMID	Same
Postback <sub>SNF</sub>	Zero since ETC <sub>NF</sub> is recalculated to capture changes to the Transmission Service Requests	Zero since ETC <sub>NF</sub> is recalculated to capture changes to the Transmission Service Requests and/or schedules, with the exception of AC N>S
Counterflows <sub>NF</sub>	Included with schedules	Same

708 **Where:**

709 **ATC<sub>NF</sub>** is the non-firm Available Transfer Capability for the ATC path for that period for which  
710 **ATC<sub>NF</sub>** is being calculated.

711 BPA calculates six **ATC<sub>NF</sub>** values as described above.

712 **TTC** is the Total Transfer Capability of the ATC path for that period.

713 **ETC<sub>F</sub>** is the sum of existing firm commitments for the ATC path as specified in WEQ-023 during  
714 that period for which **ATC<sub>NF</sub>** is being calculated.

715 The section below outlines how BPA calculates **ETC<sub>F</sub>** for all of its paths for the beyond  
716 Real-time and the Real-time horizons.

### 717 **ETC<sub>F</sub> for the Beyond Real-Time Horizon**

718 Reservations, and base ETC cases for flow-based paths, are used to calculate **ETC<sub>F</sub>** for the  
719 Beyond Real-time horizon. When calculating **ETC<sub>F</sub>** for this horizon, *de minimis* impacts of  
720 reservations across flow-based paths are deemed to be zero.

721 For **ATC<sub>NF</sub>** calculations for the beyond Real-time horizon, BPA utilizes the following  
722 variables within its ATC software to calculate **ETC<sub>F</sub>**:

723  $ETC_F = LRES + SRES - SADJ/ETC \text{ Adjustments} + NFETC$

724 **Where:**

725 **LRES** is the sum of positive impacts of BPA's Long-Term Reservations.

726 **SRES** is the sum of positive impacts of BPA's Short-Term Reservations.

727 **SADJ/ETC Adjustments** is the variable used to make adjustments to  $ETC_F$  not captured  
728 in LRES or SRES.

729 BPA applies one such adjustment to allow for deferral competitions, as required in  
730 Section 17.7 of BPA's OATT. When a deferral reservation is confirmed, BPA applies a  
731 SADJ/ETC Adjustment to hold out capacity for the time period deferred, starting at  
732 the latter of five months out or the service commencement date of the original  
733 reservation, to allow for a competition. At four months out, if no competition is  
734 identified, the SADJ/ETC Adjustment is modified to add back capacity for the fourth  
735 month out.

736 BPA uses SADJ/ETC Adjustments to ensure accurate accounting of  $ETC_F$ . These  
737 adjustments may be performed to account for situations such as data modeling  
738 corrections, and are noted in the descriptions of the adjustments.

739 **NFETC** is used to ensure that the amount of  $NITS_F$ ,  $GF_F$ ,  $PTP_F$  and  $ROR_F$  capacity BPA  
740 sets aside in the LRES variable for contracts where BPA gives customers the right to  
741 schedule the capacity reserved between multiple PORs and PODs does not exceed the  
742 total capacity specified in those contracts.

743 **NFETC** is also used to align the ETC calculated in the power flow base case along with  
744 additional PTDF calculations in order to balance to the standard OATI calculation.

745 This adjustment is derived by comparing two values: a) the impacts of the  $PTP_F$ ,  $GF_F$   
746 and  $NITS_F$  Long-Term Reservations derived from the base ETC Cases and b) the impacts  
747 of the same reservations calculated using PTDF Analysis for each flow-based path. The  
748 adjustment for each flow-based path is equal to the difference of these two values.

749 BPA has begun to transition the modeling of Conditional Firm reservations into the ETC  
750 cases. This transition started with the Summer 2024 studies and will be completed  
751 with the Spring 2025 cases. The impacts of Conditional Firm reservations are beings  
752 managed either through **NFETC** or **SADJ/ETC Adjustments** during the transition period.

753  
754

The following diagram illustrates how the variables in BPA’s ATC software correspond to the variables in the ETC<sub>F</sub> algorithm for the Beyond Real-time horizon.

ETC <sub>F</sub> =	NITS <sub>F</sub>	+	GF <sub>F</sub>	+	PTP <sub>F</sub>	+	ROR <sub>F</sub>
	↓		↓		↓		↓
	LRES		LRES		LRES		LRES
	+				+		
	SRES				SRES		
	+		+		+		+
	NFETC		NFETC		NFETC		NFETC
	-		-		-		-
	SADJ/ETC Adjustments		SADJ/ETC Adjustments		SADJ/ETC Adjustments		SADJ/ETC Adjustments

755 ETC<sub>F</sub> for the Real-Time Horizon

756 For ATC<sub>NF</sub> calculations for the Real-time horizon, BPA divides ETC<sub>F</sub> into the following  
757 variables within its ATC software:

758 
$$ETC_F = SCH^+_7 + ASC^+_7 + RADJ/ETC \text{ Adjustment}$$

759 Schedules are used to calculate ETC<sub>F</sub> for the Real-time horizon. When calculating ETC<sub>F</sub> for  
760 this horizon, *de minimis* impacts of schedules across flow-based paths are included in  
761 ETC<sub>F</sub>.

762 **Where:**

763 **SCH<sup>+</sup><sub>7</sub>** is the sum of the positive impacts of schedules that reference confirmed NITS<sub>F</sub>,  
764 GF<sub>F</sub> and PTP<sub>F</sub> reservations for the ATC path for that period. The energy profile of the  
765 schedule is used except for the schedule types of Dynamic, Capacity and Pseudo-tie.

766 **ASC<sup>+</sup><sub>7</sub>** is the sum of the positive impacts of dynamic schedules that reference  
767 confirmed NITS<sub>F</sub>, GF<sub>F</sub> and PTP<sub>F</sub> reservations for the ATC path for that period. The  
768 transmission profile of the schedule is used for the schedule types of Dynamic,  
769 Capacity and Pseudo-tie.

770 **RADJ/ETC Adjustment:** BPA uses RADJ/ETC adjustments to ensure accurate  
771 accounting of ETC<sub>F</sub>. These adjustments may be performed to account for situations  
772 such as data modeling corrections.

773 The following diagram illustrates how the variables in BPA’s ATC software correspond  
 774 to the variables in the ETC<sub>F</sub> algorithm for the Real-time horizon. ROR<sub>F</sub> is not included  
 775 in ETC<sub>F</sub> for the Real-time horizon because ROR<sub>F</sub> is not relevant for the Real-time  
 776 horizon.

<b>ETC<sub>F</sub> =</b>	<b>NITS<sub>F</sub></b>	<b>+</b>	<b>GF<sub>F</sub></b>	<b>+</b>	<b>PTP<sub>F</sub></b>
	↓		↓		↓
	<b>SCH<sup>+</sup><sub>7</sub></b>		<b>SCH<sup>+</sup><sub>7</sub></b>		<b>SCH<sup>+</sup><sub>7</sub></b>
	<b>+</b>		<b>+</b>		<b>+</b>
	<b>ASC<sup>+</sup><sub>7</sub></b>		<b>ASC<sup>+</sup><sub>7</sub></b>		<b>ASC<sup>+</sup><sub>7</sub></b>
	<b>+</b>		<b>+</b>		<b>+</b>
	<b>RADJ/ETC Adjustment</b>		<b>RADJ/ETC Adjustment</b>		<b>RADJ/ETC Adjustment</b>

777 ETC<sub>NF</sub> is the sum of existing non-firm commitments for the ATC path as specified in WEQ-023  
 778 during that period for which ATC<sub>NF</sub> is being calculated.

779 The section below outlines how BPA calculates ETC<sub>NF</sub> for all of its paths for the beyond  
 780 Real-time and the Real-time horizons.

781 **ETC<sub>NF</sub> for the Beyond Real-Time Horizon**

782 For ATC<sub>NF</sub> calculations for the beyond Real-time horizon, ETC<sub>NF</sub> is reflected as the  
 783 following variable within BPA’s ATC software:

784 **ETC<sub>NF</sub> = RRES<sub>6,5,4,3,2,1</sub>**

785 Reservations are used to calculate ETC<sub>NF</sub> for the Beyond Real-time horizon. When  
 786 calculating ETC<sub>NF</sub> for this horizon, *de minimis* impacts of reservations across flow-based  
 787 paths are deemed to be zero.

788 **Where:**

789 **RRES<sub>6,5,4,3,2,1</sub>** is the sum of the positive impacts of all confirmed NITS<sub>NF6</sub>, PTP<sub>NF5</sub>, PTP<sub>NF4</sub>,  
 790 PTP<sub>NF3</sub>, PTP<sub>NF2</sub> and PTP<sub>NF1</sub> reservations.

791 The following diagram illustrates how the variables in BPA’s ATC software correspond  
 792 to the variables in the ETC<sub>NF</sub> algorithm for the Beyond Real-time horizon.

<b>ETC<sub>NF</sub> =</b>	<b>NITS<sub>NF</sub></b>	<b>+</b>	<b>PTP<sub>NF</sub></b>
	↓		↓
	<b>RRES<sub>6</sub></b>		<b>RRES<sub>5,4,3,2,1</sub></b>

793 **ETC<sub>NF</sub> for the Real-Time Horizon**

794 For ATC<sub>NF</sub> calculations in the Real-time horizon, ETC<sub>NF</sub> is reflected as the following  
 795 variables within BPA’s ATC software:

796  $ETC_{NF} = SCH^{+}_{6,5,4,3,2,1} + ASC^{+}_{6,5,4,3,2,1}$

797 To calculate  $ETC_{NF}$  for the Real-time horizon, reservations are used until schedules are  
 798 received, and then schedules are used. When calculating  $ETC_{NF}$  for this horizon, *de*  
 799 *minimis* impacts across flow-based paths are included in  $ETC_{NF}$ , regardless of whether the  
 800 reservation or schedule is being used in the calculation.

801 **Where:**

802  $SCH^{+}_{6,5,4,3,2,1}$  is the sum of the positive impacts of schedules referenced to confirmed  
 803  $NITS_{NF6}$ ,  $PTP_{NF5}$ ,  $PTP_{NF4}$ ,  $PTP_{NF3}$ ,  $PTP_{NF2}$  and  $PTP_{NF1}$  reservations, plus the sum of the  
 804 positive impacts of pending and confirmed  $NITS_{NF6}$ ,  $PTP_{NF5}$ ,  $PTP_{NF4}$ ,  $PTP_{NF3}$ ,  $PTP_{NF2}$  and  
 805  $PTP_{NF1}$  reservations that have not yet been scheduled. Once these reservations are  
 806 scheduled, the schedule is used for  $ETC_{NF}$ , thereby adding back the difference  
 807 between the reservation and schedule amounts to  $ATC_{NF}$ . The energy profile of the  
 808 schedule is used except for the schedule types of Dynamic, Capacity and Pseudo-tie.

809  $ASC^{+}_{6,5,4,3,2,1}$  is the sum of positive impacts of dynamic schedules referenced to  
 810 confirmed  $NITS_{NF6}$ ,  $PTP_{NF5}$ ,  $PTP_{NF4}$ ,  $PTP_{NF3}$ ,  $PTP_{NF2}$  and  $PTP_{NF1}$  reservations, plus the sum of  
 811 the positive impacts of pending and confirmed  $NITS_{NF6}$ ,  $PTP_{NF5}$ ,  $PTP_{NF4}$ ,  $PTP_{NF3}$ ,  $PTP_{NF2}$  and  
 812  $PTP_{NF1}$  reservations that have not yet been scheduled. Once these reservations are  
 813 scheduled, the schedule is used for  $ETC_{NF}$ , thereby adding back the difference  
 814 between the reservation and schedule amounts to  $ATC_{NF}$ . The transmission profile of  
 815 the schedule is used for the schedule types of Dynamic, Capacity and Pseudo-tie.

816 The following diagram illustrates how the variables in BPA’s ATC software correspond  
 817 to the variables in the  $ETC_{NF}$  algorithm for the Real-time horizon.

818

$ETC_{NF} =$	$NITS_{NF}$	+	$PTP_{NF}$
	↓		↓
	$SCH^{+}_6$		$SCH^{+}_{5,4,3,2,1}$
	+		+
	$ASC^{+}_6$		$ASC^{+}_{5,4,3,2,1}$

819  $CBM_s$  is the Capacity Benefit Margin for the ATC path that has been scheduled during that  
 820 period.

821 BPA does not maintain CBM and thus sets  $CBM_s$  at zero for all of its paths for all time  
 822 periods.

823  $TRM_u$  is the Transmission Reliability Margin for the ATC path that has not been released for  
 824 sale (unreleased) as non-firm capacity by the Transmission Service Provider during that  
 825 period.

826 The description of how BPA implements TRM can be found in BPA's TRMID, which is posted  
827 on BPAs website.

828 **Postbacks<sub>NF</sub>** are changes to non-firm Available Transfer Capability due to a change in the use  
829 of Transmission Service, as defined in WEQ-023.

830 The section below outlines how BPA calculates Postbacks<sub>NF</sub> for all of its paths for the  
831 beyond Real-time and the Real-time horizons.

### 832 **Postbacks<sub>NF</sub> for the Beyond Real-time horizon**

833 BPA automatically recalculates ETC<sub>NF</sub> to account for changes to Transmission Service  
834 Requests (such as request types of Recall and annulments) for the Beyond Real-time  
835 horizon. Since these types of changes to Transmission Service Requests are captured in  
836 ETC<sub>NF</sub>, BPA treats Postbacks<sub>NF</sub> as zero for this horizon.

### 837 **Postbacks<sub>NF</sub> for the Real-time Horizon**

838 BPA automatically recalculates ETC<sub>NF</sub> to account for changes to Transmission Service  
839 Requests (such as request types of Recall and annulments) and/or schedules for the Real-  
840 time Horizon. Since these types of changes to Transmission Service Requests and/or  
841 schedules are captured in ETC<sub>NF</sub>, BPA treats Postbacks<sub>NF</sub> as zero for this horizon for all  
842 paths with the exception of AC N>S.

843 For ATC<sub>NF</sub> calculations for the AC N>S path in the Real-time horizon, BPA uses a  
844 Postbacks<sub>NF</sub>, expressed as RADJ/ETC. For its hourly AC N>S non-firm calculations, BPA  
845 posts back any unused share of non-firm capacity that is available to BPA by capacity  
846 ownership and other Agreements for the AC N>S, if needed to prevent Curtailments.

847 **Counterflows<sub>NF</sub>** are adjustments to non-firm Available Transfer Capability as determined by  
848 the Transmission Service Provider and specified in its ATCID.

849 Since a schedule provides assurance that the transaction will flow, all counterflows  
850 resulting from firm and non-firm Transmission schedules, excluding tag types dynamic,  
851 pseudo and capacity, are added back to ATC<sub>NF</sub> in the Counterflows<sub>NF</sub> component.

852 In BPA's ATC<sub>NF</sub> calculations, Counterflows<sub>NF</sub> is expressed as  $SCH_{7,6,5,4,3,2,1}$ , which is the sum  
853 of schedules flowing in the direction counter to the direction of the path.

854 Counterflows are modeled in the ETC Cases used to determine ETC<sub>F</sub> for BPA's flow-based  
855 paths. In instances where the power flow study results in a negative base ETC value, BPA  
856 uses zero as the base ETC for purposes of calculating ATC<sub>NF</sub>. This is done to ensure that  
857 BPA does not make capacity available as a result of counterflows that may or may not  
858 materialize in real-time

859 In some cases, the amount of Counterflows<sub>NF</sub> exceeds the sum of the ETC<sub>F</sub> and ETC<sub>NF</sub>,  
860 which, when added to TTC, results in ATC<sub>NF</sub> greater than TTC.

861 Note: The variable RADJ/ETC is also used to respond to a BPA dispatcher order to change ATC  
862 values by a specified amount and thereby reduce schedules in-hour when the flow exceeds  
863 the TTC.



## 864 **Adjustments to Flow-based Path ATC Values**

865 There may be instances where BPA needs to perform testing in the production environment of  
866 BPA's ATC software, or add flow-based paths in advance of their effective date. In these  
867 instances, BPA will adjust its ATC values across the flow-based paths to ensure that  
868 Transmission Service Requests are not refused due to lack of ATC across the flow-based paths.  
869 BPA will notify customers prior to events that require these types of adjustments to ATC  
870 values.

---

## 871 **VIII. Responding to Methodology/Documentation Clarifications and/or** 872 **Data Requests**

---

873 BPA will respond to all written requests for clarification of its TTC/TFC methodology, ATCID,  
874 CBMID, or TRMID from any registered entity that demonstrates a reliability need within 45  
875 days of receiving the written request. Methodology and/or documentation clarification  
876 requests should be sent to [nercatcstandards@bpa.gov](mailto:nercatcstandards@bpa.gov) with "**Methodology/Documentation**  
877 **Clarification**" in the subject line.

878 BPA will respond to written data requests from any Transmission Service Provider or  
879 Transmission Operator, solely for use in the requestor's ATC or AFC calculations, within 45  
880 calendar days of receiving the written request. For a Transmission Service Provider or  
881 Transmission Operator to officially request data to use in ATC or AFC calculations, the  
882 requestor must fill out the **Data Request Form** found on BPA's ATC Methodology website.  
883 The completed request form must be sent to [nercatcstandards@bpa.gov](mailto:nercatcstandards@bpa.gov) with "**Data Request**  
884 **Form**" in the subject line.

---

## 885 **IX. ATCID Revisions**

---

886 BPA posts this ATCID in accordance with NAESB Business Practice Standard WEQ-001.